

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/EH/2023/SZ/ 841

Dated. 25/07/2023

FIRE SAFETY CERTIFICATE

Certified that the Eating house in the Name & Style of M/s Cafe Tesu located at Ground floor 4 Aurobindo Marg, Near IIT Fly Over, New Delhi 110016 comprised of Ground floor owned/occupied by Essex Farms Pvt. Ltd was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/SZ/2020/182 Dated 17/12/2020. The restaurant premise was re-inspected by the officer concerned of this department on 19/07/2023 in the presence of Mr. Sandeep Goyal (owner) of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class D "Assembly Building" (Restaurant) and validity upto 31/03/2026 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/07/2023 at New Delhi by

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Dy. Health Officer, MCD, Public Health Department, Aurobindo Marg, Green Park, Delhi-110016 (Ref. MHA Portal ID 2023071212449 dated 14-07-2023)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

N/15

INSPECTION REPORT

1	Name & Address of the Building	M/s Cafe Tesu (A Unit of Essex Farm Pvt. Ltd) located at 4, Aurobindo Marg, New Delhi-110016		
2	Type of Occupancy	Assembly 'Group-D'		
3	Building comprised of	Ground floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/SZ/2020/182 Dated 17/12/2020		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2011/737 dated 24/04/2011		
7	Date of Inspection	19/07/2023		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Sandeep Goyal (owner)		
10	Year of construction	1962 & 2019		
11	Applicant letter No.	MHA Portal ID 2023071212449 dated 14-07-2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	6 mtr 4.5 mtr 6 mtr	09 m 05 m Provided	MR MR MR
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	N/A -NA-	Restt. at GF only N/A	N/A N/A
	b. Width of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	-NA- -NA-	N/A N/A	N/A N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	-NA- -NA-	N/A N/A	N/A N/A
	d. No. of continuous staircase to terrace	-NA-	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2m & 1.5 m	2m & 1.5 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	-NA- -NA- -NA- -NA- -NA-	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	-NA- Required	N/A Provided	N/A MR
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	Required ABC / CO2 ISI marked	06 Nos ABC & Co2 Provided	MR MR MR
6	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	One (near rest) 30m 5mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hoover's location 	Required Required -NA- Required Required	Smoke / Heat Provided N/A Provided Provided	MR MR N/A MR MR

4/16

8	MOEFA	Required	Provided	MR
9	Public Address System	-NA-	-NA-	-NA-
10	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	Required	Provided	MR
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11	Internal Hydrants.			
	• Size of Riser/Down-comer	100mm	Provided	MR
	• Number of Hydrant per floor	Required	Provided	MR
	• Hose box.	Required	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting / Manual Stopping.	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	• Terrace Level	Common pumping arrangement		
	➤ Discharge of pump.	Required	Provided	MR
	➤ Head of pump.	Required	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	Captive water storage for Fire Fighting.	Common water storage tank		
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	20,000 Ltr	30,000 Ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19	Fire Control Room.			
	• Detector System Panel.	Required	Provided	MR
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.	✓ -NA-	-NA- ✓	-NA-

N/M

M/s Cafe Tesu (A Unit of Essex Farm Pvt. Ltd) located at 4, Aurobindo Marg, New Delhi-110016

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/SZ/2020/182 Dated 17/12/2020, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Me 10
Signature of the Inspection Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

Sh
Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

CFO (HQ)

Sh
25/07/2023

Director / Sh
25/07/23

FP 175

ADO/BCP

As approved, F.T. letter is put up for your signature pl

Director / Sh
25/07/23

Sh
25/7/2023

Sh

Uploaded
31/7/23
Sh