

69

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/2023/School/ 536

Dated: 03/08/2023

FIRE SAFETY CERTIFICATE

Certified that the Jagat Vidhya Sanatan Dharm Girls Sr. Sec School located at D-2, Link Road, Karol Bagh, New Delhi -110005 is comprised of B+ Gr.+02 Upper Floor, was inspected by the officer concerned of this department on 26-07-2023 in the presence of Smt. Manju Soni, V. Principal and found that the said school building has complied with the fire prevention and fire safety requirements in accordance with a circular of Director of Education 2011 and that the premises except basement is fit for occupancy of class Group B "Educational Building" (Sub-Div. B-I) with effect from ... 03/08/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on ... 03/08/2023 ... at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Civic Center, New Delhi.
2. Director of Education, Govt. of NCT, Old Sec. Delhi.
3. The Principal, Jagat Vidhya Sanatan Dharm Girls Sr. Sec School, D-2, Link Road, Karol Bagh, New Delhi -110005.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned and basement is closed and shall not be used for any purpose.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1. Name & address of the building:- **Jagat Vidhya Sanatan Dharm Girls Sr. Sec School at D-2, Link Road , Karol Bagh, New Delhi -110005**
Educational Group B-I, B+ Gr.+02 Upper Floor
2. Type of occupancy:- **New**
3. Type of case:- **N/A**
4. Details of previous FSC:- **N/A**
5. Fire safety directives No.- **as per Dir. of Education circular - 2011**
6. Date of inspection:- **26/07/23**
7. Name of the inspecting officer:- **Sh. Ravinder Singh(ADO/CC)**
8. Name & designation of officer
From the building side:- **Smt Manju Soni, V.Principal**
9. Year of construction:- **Old(existing) -1972**
10. Applicant's letter No:- **mail id jvsdprincipal2015@gmail.com dated 07.07.2023**

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement as per UBBL-2016 /NBC part-4 / Dir. of Edu.	Provided at site	Remarks MR/NMR
				New
1.	Access to Building			
	1) Road width	06 mtr.	06 mtr.	MR
	2) Gate width	4.5 mtr.	4.5 mtr.	MR
	3)Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	04 Nos.	04 Nos.	MR
	2. Basements	01 Nos.	01 Nos.	MR
	B. Width of staircase			
	1. Upper floors	1.5 mtr.	2x1.7 mtr. & 2x1,50 meter	MR
	2. Basements	1.5 mtr.	Provided	MR
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	02	02	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size (class room)	1.0 meter	1.00mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A



6

N/6

5.	Fire Extinguishers			
	1) Total numbers	16 Nos.	16 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	N/A	N/A	N/A
6.	First-Aid Hose Reel			
	1) Total number of each floor	02nos	Provided	MR ✓
	2) Length of hose reel hose	30 mtr	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement(< 200 m2)	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR ✓
	b) Head of pump	40 mtr	40 mtr	MR ✓
	c) Power supply	Required	Provided	MR ✓
	d) Auto starting of pump	Required	Provided	MR ✓
14.	Captive Water Storage for Fire Fighting			

✓


N/17

	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10000 liter	Provided	MR ✓
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the substantial compliance of the minimum standards of fire prevention and fire safety measures as required under DFS Rules 2010, if agreed, we may issue the FSC to said premises. Accordingly reply letter is prepared and put up for kind perusal and signature pl.

Signature of the Inspecting Officer



Name :- Ravinder Singh
Designation :- ADO (CC)

Daxco
26/7/23
Dy. C.F.O. (S2)
C.F.O.
28/07/2023
Director
27/07/23
Ap44