



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI

No: F6/DFS/MS/School/WZ/2023/524

Dated: 03/08/2023

FIRE SAFETY CERTIFICATE

Certified that the M.C.D Primary School located at Tatarpur, New Delhi – 110027, comprised of Ground plus One Upper floor, Owned/Occupier by M.C.D Primary School, was issued FSC vide letter No. F6/DFS/MS/WZ/2020/School/155 dated 13/04/2020. The premises was re-inspected by the officer concerned by this department on 25/07/2023 in the presence of Smt. Asha (Principal) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have deemed complied with fire prevention & fire safety requirements in accordance with DOE Circular No. F16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01/03/2011 issued by the Directorate of education and found that the premises is fit for occupancy class “Educational” (Group - B) with effect from 03/08/2023 for a period of three years subject to the compliance of the conditions mentioned below:-

Issued on 03/08/2023 at New Delhi.

(Atul Garg)
Director

Copy to:

1. The Principal/Incharge, MCD Primary School, located at Tatarpur, New Delhi-110027.
2. Director of Education, Old Sectt. Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/15

INSPECTION REPORT

1. Name & address of the building : MCD Primary School, Located at Tatarpur, New Delhi – 110027. (School ID-1556066)
2. Type of Occupancy : Educational (Ground + 1 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/2020/School/155 dated 13/04/2020
5. Fire Safety directives letter No : DOE Circular NO -3298-3398 dated 01/03/2011
6. Date of inspection : 25/07/2023
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (MN)
8. Name and designation of officers from the building side : Smt. Asha (Principal)
9. Year of Construction : 2014 (As per previous insp. report dtd.- 18/03/2020)
10. Applicant's letter No. : Email dated 12/07/2023

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Required as per Rule 35(6) of DFS Rule 2010 | Provided at site | Remarks MR/NMR |
|--------|---|---|--------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | 06 mtr | 07m Provided | MR |
| | • Gate width | Accessible | 396 cm Provided | MR |
| | • Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 02 | 02 Provided | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper Floors | 1.5m | 2 x 150cm Provided | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | e. No. of continuous staircases to terrace | NA | NA | NA |
| | f. Width of Corridor | 1.5m | 210cm Provided | MR |
| | g. Door Size | 1 m | 116cm Provided | MR |
| 3 | Compartmentation. | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | NA | NA | NA |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 08 nos. | Provided | MR |
| | • Types | CO ₂ , ABC type | Provided | MR |
| | • IS marking | ISI marked | Provided | MR |
| 6 | First-Aid Hose Reels. | | | |
| | • Total numbers on each floor | NA | NA | NA |
| | • Length of hose reel hose | NA | NA | NA |
| | • Nozzle diameter | NA | NA | NA |

L

8/1

| N/16 | | | |
|------|--|----|----|
| 7 | Automatic fire detection and alarming system. | | |
| | • Type of detectors | NA | NA |
| | • Location of Main Panel | NA | NA |
| | • Location of Repeater Panel | NA | NA |
| | • Alternate source of power | NA | NA |
| | • Hooters' Location | NA | NA |
| 8 | MOEFA | | |
| 9 | Public Address System. | | |
| | | NA | NA |
| 10 | Automatic Sprinkler System. | | |
| | • Basement | NA | NA |
| | • Upper Floor | NA | NA |
| | • Sprinkler above false ceiling | NA | NA |
| 11 | Internal Hydrants | | |
| | • Size of riser/down-comer | NA | NA |
| | • Number of hydrants per floor | NA | NA |
| | • Hose Box | NA | NA |
| 12 | Yard Hydrants. | | |
| | • Total number of hydrants | NA | NA |
| | • Hose Box | NA | NA |
| 13 | Pumping Arrangements. | | |
| | • Ground Level | | |
| | ➤ Discharge of main Pump | NA | NA |
| | ➤ Head of Main pump | NA | NA |
| | ➤ Number of main pumps | NA | NA |
| | ➤ Jockey Pump out put | NA | NA |
| | ➤ Jockey pump head | NA | NA |
| | ➤ Standby Pump out put | NA | NA |
| | ➤ Standby Pump Head | NA | NA |
| | ➤ Auto Starting/ Manual stopping | NA | NA |
| | ➤ Pump House Access | NA | NA |
| | • Terrace level | | |
| | ➤ Discharge of pump | NA | NA |
| | ➤ Head of the pump | NA | NA |
| | ➤ Power Supply | NA | NA |
| | ➤ Auto Starting of pump | NA | NA |
| 14 | Captive Water Storage for fire fighting. | | |
| | • Underground tank capacity | NA | NA |
| | ➤ Draw-off connection | NA | NA |
| | ➤ Fire service inlet | NA | NA |
| | ➤ Access to tank | NA | NA |
| | • Overhead Tank capacity | NA | NA |
| 15 | Exit Signage. | | |
| | | NA | NA |
| 16 | Provision of Lifts. | | |
| | • Pressurization of Lift Shaft | NA | NA |
| | • Pressurization of Lift lobby | NA | NA |
| | • Communication In lift Car | NA | NA |
| | • Fireman's Grounding Switch | NA | NA |
| | • Lift Signage | NA | NA |

| | | | | |
|----|--|----|----|----|
| | Standby power supply | NA | NA | NA |
| | Refuge Area. | | | |
| | ➤ Total Area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Batter backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | NA | NA | NA |

The fire protection system provided in the building was test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety measure as required under the rules the FSC issued vide letter No. F6/DFS/MS/WZ/2020/School/155 dated 13/04/2020 renewal under rule DOE Circular No. 3298-3398 dated 01/03/2011 is recommended.

0/ADO/MN
26/7/23

DO (C. Div)

DO

28/7/23

CFO Wing
31/7/2023

Director WY
11/8/23

ADO/MN

Sir, F.T is put up for your kind personal & signature please.

DO
01/8/23

DO
26/7/2023
Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)