



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI

No: F6/DFS/MS/School/WZ/2023/527

Dated: 03/08/2023

FIRE SAFETY CERTIFICATE

Certified that the Nigam Utkrist Vidyalaya located at Mansarovar Garden, New Delhi-110015, comprised of Ground plus One Upper floor, Owned/Occupied by Nigam Utkrist Vidyalaya, was issued FSC vide letter No. F6/DFS/2020/13 dated 21/01/2020. The premises was re-inspected by the officer concerned by this department on 25/07/2023 in the presence of Smt. Savita Chadha (Incharge) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have deemed complied with fire prevention & fire safety requirements in accordance with DOE Circular No. F16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01/03/2011 issued by the Directorate of education and found that the premises is fit for occupancy class "Educational" (Group - B) with effect from 03/08/2023 for a period of three years subject to the compliance of the conditions mentioned below:-

Issued on 03/08/2023 at New Delhi.

(Atul Garg)
Director

Copy to:

1. The Principal/Incharge, Nigam Utkrist Vidyalaya located at Mansarovar Garden, New Delhi-110015,
2. Director of Education, Old Sectt. Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : Nigam Utkrist Vidyalaya
Located at Mansarovar Garden, New Delhi-110015. (School ID-1556162)
2. Type of Occupancy : Educational (Ground + 1 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2020/13 dated 21/01/2020
5. Fire Safety directives letter No : DOE Circular NO -3298-3398 dated 01/03/2011
6. Date of inspection : 25/07/2023
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (MN)
8. Name and designation of officers from the building side : Smt. Savita Chadha (Incharge)
9. Year of Construction : 2018 (As per previous insp. report dtd.- 30/12/2019)
10. Applicant's letter No. : Outdoor Diary No.-2840 dated 15/06/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	2 x 150cm Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	1.5m	210cm Provided	MR
	g. Door Size	1 m	1.10 m Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	06 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
		NA	NA	NA

6/8

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA		
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
8	MOEFA	NA	NA		NA
9	Public Address System.	NA	NA		NA
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA		NA
		NA	NA		NA
		NA	NA		NA
11	Internal Hydrants				
	<ul style="list-style-type: none"> Size of riser/down-comer' Number of hydrants per floor Hose Box 	NA	NA		NA
		NA	NA		NA
		NA	NA		NA
12	Yard Hydrants.				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA		NA
		NA	NA		NA
13	Pumping Arrangements.				
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
14	Captive Water Storage for fire fighting.				
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
15	Exit Signage.	NA	NA		NA
16	Provision of Lifts.				
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby 	NA	NA		NA
		NA	NA		NA
		NA	NA		NA

	Standby power supply	NA	NA	NA
Refuge Area.				
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
9	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection system provided in the building was test checked and found functional at the time of inspection.

ADOMN
07/2023

In view of the deemed compliance of minimum standards on fire prevention and fire safety measure as required under the rules the FSC issued vide letter No. F6/DFS/MS/2020/13 dated 21/01/2020 renewal under rule DOE Circular No. 3298-3398 dated 01/03/2011 is recommended. for approval pl.

[Signature]
26/7/2023

Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)

[Signature]
20/6/2023

[Signature]
28/7/23

[Signature]
28/7/2023

Director
[Signature]
13/11/2023

[Signature]
Anuj

Sir, F.T is put up for your kind personal & signature please.

[Signature]
11/8/23
M

[Signature]
01/8/2023