

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F.6/DFS/MS/Industry/2023/SZ/ 373

Dated: 07/08/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s **Bharat Adhesives**, A-36, Mayapuri Industrial Area, Phase-II, New Delhi-110064 comprised of basement and ground floor only owned/occupied by M/s **Bharat Adhesives** was issued FSC by this department vide letter no. **F.6/DFS/MS/Industry/2020/SZ/333 dated 25/08/2020**. The Industrial building was re-inspected by the officers concerned of this department on 24/07/2023 in the presence of Sh. Prankul Nijhawan (Partner) and found that the industrial building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class Group "G" "Industrial Building" w.e.f. the date of issue of this certificate for a period of **three** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on.....07/08/2023.....at New Delhi.


(Atul Garg)
Director
Delhi Fire Service
9/9

Copy to:-

1. The Executive Engineer (Bldg.),
HQ-II, SDMC, 8th Floor, Dr. SPM Civic Centre, E-Wing,
J.L. Nehru Marg, New Delhi-110002
2. The Partner, M/s **Bharat Adhesives**, A-36, Mayapuri Industrial Area, Phase-II,
New Delhi-110064.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s Bharat Adhesives, A-36, Mayapuri Industrial Area, Phase-II, New Delhi-110064
2. Building comprised of : Basement & ground floor only
3. Type of Occupancy : Industrial Building.
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/Industry/2020/SZ/333 dated 25/08/2020
6. Fire Safety directives letter No : F.6/DFS/MS/BP/2003/617 dated 24.03.03
7. Date of inspection : 24/07/2023
8. Name of Inspecting Officer : A.D.O. R.K. Yadav & D.O Vedpal Chhikara
9. Name and designation of officers
From the building side : Sh. Prankul Nijhawan (Partner)
10. Year of Construction : Before 2003
11. Applicant's letter No. : E-mail dated 12/07/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	09 m 05 m N/A	Provided Provided N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	N/A Two	N/A Two	N/A M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	N/A 1.25 m	N/A 1.33 & 1.35 m	N/A M/R
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	1.25 m	Provided	M/R
	f. Exit Door Size	1.0 m	Provided	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required N/A N/A N/A N/A	Provided N/A N/A N/A N/A	M/R N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements 	Required	Exhaust fans are provided	M/R
	<ul style="list-style-type: none"> Upper floors 	N/A	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	05 no.'s W/CO ₂ / CO ₂ type ISI marked	Provided Provided ISI marked	M/R M/R M/R

	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 36 mtrs. 5 mm	Provided Provided Provided	M/R MR MR
	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Required Required	Provided Provided	M/R M/R
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	1620 LPM 55 mtrs. One 180 LPM 55 mtrs. 1620 LPM 55 mtrs. Required	Provided Provided Provided Provided Provided Provided Provided	M/R M/R M/R M/R M/R M/R M/R
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	Required 450 LPM 30 Mtrs Required Required	Provided Provided Provided Provided	M/R M/R M/R M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	35000 ltrs Required Required Required 10,000 Ltrs. Required	Provided Provided Provided Provided Provided	M/R M/R M/R M/R M/R
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A

N/14

Standby power supply	N/A	N/A	N/A
Refuge Area.			
➤ Total Area	N/A	N/A	N/A
➤ Location	N/A	N/A	N/A
Fire Control Room			
• Detector System Panel	N/A	N/A	N/A
• Flow Switch Panel	N/A	N/A	N/A
• PA System Panel	N/A	N/A	N/A
• Battery backup	N/A	N/A	N/A
• Building Floor Plans	N/A	N/A	N/A
Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/Industry/2020/SZ/333 dated 25/08/2020 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of Inspecting Officer
Name:- Vedpal Chhikara
Designation:- Divisional Officer

Signature of Inspecting Officer
Name:- R.K. Yadav
Designation:- Asstt. Divisional Officer

CFO (S2) 28/8/2023

Director 21/8/23

ADDY/20/1

F T better to put up for sign Mease

DIRECTOR 21/8/23

RKec 31/8/2023