

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F.6/DFS/MS/CNG/2023/SZ/ 374

Dated: 07/08/2023

FIRE SAFETY CERTIFICATE

Certified that the CNG Station at Khasra No. 63, Killa No. 9/2, Village-Mitraon, Tehsil Najafgarh, South West Delhi, New Delhi-110043, comprised of ground floor only, (04 Dispenser with 08 points) owned/occupied by M/s Indraprastha Gas Limited. The premises was inspected by the officer concerned of this department on 05/08/2023 in the presence of Sh. Sandeep Shokeen (owner) and found that CNG Dispensing Station have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises (CNG Dispensing Station) is fit for occupancy Class "J" Hazardous Building w.e.f. the date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on..... 07/08/2023at New Delhi.

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Vice-President (F&S),
Indraprastha Gas Limited, IGL Bhawan, Plot No.-4,
Community Centre, Sector-9, R.K.Puram, New Delhi-110022
2. The Joint C.P. (Lic.),
Police Station, Defence Colony, New Delhi

Following fire safety directives must be adhered to -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : CNG Station at khasra No. 63, Killa No. 9/2, Village- Mitraon, Tehsil Najafgarh, South West Delhi, New Delhi-110043.
2. Type of Occupancy : Group "J" Hazardous (CNG Facility)
3. Building comprised of : Ground floor only.
4. Type of Case : New
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : Nil
7. Date of inspection : 05/08/2023
8. Name of Inspecting Officer : ADO R.K. Yadav
9. Name and designation of officers
From the building side : Sh. Sandeep Shokeen (Owner)
10. Year of Construction : 2020-21
11. Applicant's letter No. : IGL/CNGPRJ/NOC/03082023 dated 04/08/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NFPA/CCOE/OISD etc. requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	12 m	45 m Provided	MR
		NA	Directly accessible from road	NA
		NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	NA	NA	NA
		NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	NA	NA	NA
		NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA	NA	NA
		NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
		NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA	NA	NA
		NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 Nos.	Provided	MR
		Required	6 Nos. DCP Type (9 kg). 3 Nos. CO2 Type 4.5 kg. 2 Nos. DCP Type (75 kg) trolley mounted	MR
		ISI	Provided	MR

N/11

5.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			MR
	• Gas and flame detectors	Required	Provided	NA
	• Location of Main Panel	Required	Office at GF	NA
	• Location of Repeater Panel	NA	NA	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	At station	MR
		Required	Provided	NA
8.	MOEFA	NA	NA	
9.	Public Address System			
10.	Automatic Sprinkler System			NA
	• Basement	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			NA
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			NA
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
		NA	NA	NA
	➤ Pump House Access			
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	No Smoking Signage.	Required	Provided	MR

[Handwritten signatures]

2/12

Provision of Lifts.			
<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
17. Standby power supply	NA	Provided (DG Set)	NA
18. Refuge Area.			
<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NA	NA	NA
	NA	NA	NA
19. Fire Control Room			
<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
20. Special Fire Protection System for Protection of special Risks, if any:	CO ₂ flooding system in compressor	Provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 (3) of the Delhi Fire Service Rules 2010.

Note: Sand buckets are provided in the premises & No smoking boards adequately displayed in English and Hindi.

Advance fire water mist cum foam trolley is provided.

Two hand held explosive meters are also provided.

R. K. Yadav
 07/08/2023
 Signature of Inspecting Officer
 Name:- R.K. Yadav
 Designation:- Asstt. Divisional Officer

D.O (South West)

CFo (S2)

Director

NSK