



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/C-Hall/2023/NDZ / 371

Dated: 04/08/2023

FIRE SAFETY CERTIFICATE

Certified that the DDA Utsav Sthal (Temporary) located at CBD Ground Shahdara, Delhi-110032 building is comprised of ground (temporary structure) & ground plus one upper floor, owned/occupied by Delhi Development Authority. The premises was inspected by the officers concerned of this department in the presence of Mr. Himanshu (Supervisor), Manager on dated 26/06/2023 and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the building/premises is fit for occupancy Group 'D' "Assembly" with effect from 04/08/2023 is valid up to 31/03/2026 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 04/08/2023 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

To,

The Executive Engineer (Elect)
Delhi Development Authority
Electrical Division - 1
Seed Bed Park School Block, Shakarpur, Delhi-92

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/A

INSPECTION REPORT

1. Name & address of the building : DDA Utsav Sthal (Temporary),
CBD Ground Shahdara, Delhi-110032
2. Building is comprised of : Ground & Ground + one upper floor
3. Type of Occupancy : Assembly
4. Type of Case : New
5. Details of Previous NOC letter : Nil
6. Fire Safety direction letter No. : F.6/DFS/MS/BP/2021/Misc/1763 dt 06/09/21
7. Date of Inspection : 26/06/2023
8. Name of the Inspecting officers : DO, A.K. Jaiswal & ADO Deepak Kumar
9. Name and designation of Officer from the building side : Sh. Himanshu (Supervisor)
10. Year of Construction : 2021
11. Applicant's letter no. : F23(23)/EE/ELD-I/DDA/2023-24/1745
dated-26/05/2023

Sr. No	Minimum Standards on Fire Prevention and Fire Safety U/R33	Directive Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	09 mtr	40 mtr	MR
	• Gate width	5.00 mtr x 2	5.00 mtr x 2	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	02 nos.	02 nos.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper floor	1.50 mtr	1.50 mtr	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	1.00 nos.	1.00 nos.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2.00 mtr	2.00 mtr	MR
	g. No of door	02 nos.	02 nos.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Ventilated	MR
05.	Fire Extinguishers			
	• Total numbers	09 nos.	10 nos.	MR
	• Types	ABC /CO ₂	ABC/Co ₂	MR
	• IS marking	ISI marked	ISI marked	MR

Se ✓

N/10

06	First-Aid-Hose Reels.			
	• Total numbers on each floor	01 nos.	01 nos.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	900 LPM	900 LPM	MR
	• Head of the pump	40m	40m	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
	•			
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	25,000 Ltr.	25,000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR

SP1

N/11

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:			

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule. It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Deepak
 Signature of the Inspecting Officer
 Name : Deepak Kumar
 Designation : ADO (Shd)
 21/07/2023

A.K. Jaiswal
 Signature of the Inspecting Officer
 Name : A.K. Jaiswal
 Designation : DO (ED)
 21/07/2023

Dy. CFO (NDZ)
24/07/23

CFO. Re examine draft FSC & put up accordingly

Dy. CFO (NDZ)

24/07/23

26/7/2023

DO (ED) Sir,

Need full done.

Dy. CFO (NDZ)

27/7/2023