

C44

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2023/SZ/534

Dated: 07/08/2023

FIRE SAFETY CERTIFICATE

Certified that the M.H.D.C. Saraswati Bal Mandir, B-1, Janakpuri, New Delhi-110058, comprised of ground floor plus two upper floors, having total 23 rooms (Including Class Rooms, Offices, Sci. Lab, Comp. Lab, Sports Room, Hall & Store etc.) owned/occupied by Samarth Shiksha Samiti, Delhi (Regd.) was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2020/SZ/303 dated 24/08/2020. The School building was re-inspected by the officer concerned of this department on 26/07/2023 in the presence of Smt. Ritu Sood (Principal) and found that the school building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....07/08/2023..... at New Delhi.


(Atul Garg)
Director
Delhi Fire Service


Copy to:-

1. The Principal,
M.H.D.C. Saraswati Bal Mandir,
B-1, Janakpuri, New Delhi-110058
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/20

INSPECTION REPORT

1. Name & address of the building : M.H.D.C. Saraswati Bal Mandir, B-1, Janakpuri, New Delhi-110058.
2. Building comprised of : Ground plus two upper floors.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/School/2020/SZ/303 dated 24/08/2020
6. Fire Safety directives letter No : N/A
7. Date of inspection : 26/07/2023
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Smt. Ritu Sood (Principal)
10. Year of Construction : 2005-06
11. Applicant's letter No. : Email dated 11/07/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 06 m 4.5 m N/A	09 m 4.4 m N/A	MR MR being old case N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 No's	02 No's	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floor	1.50 & .75 m	1.38 & 1.25 m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	One	MR
	e. Width of Corridor	1.50 m	2.45 m	MR
	f. Door Size	1.0 m	1.0 m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	12 no.'s	Provided	MR
	• Types	ABC/ CO ₂ type	Provided	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01 no.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

ls h

a

7.	Automatic fire detection and alarming system		
		N/A	N/A
	• Type of detectors	N/A	N/A
	• Location of Main Panel	N/A	N/A
	• Location of Repeater Panel	N/A	N/A
	• Alternate source of power	N/A	N/A
	• Hooters' Location	N/A	N/A
8.	MOEFA		
9.	Public Address System		
10.	Automatic Sprinkler System		
	• Basement	N/A	N/A
	• Ground Floor	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A
11.	Internal Hydrants		
	• Size of riser/down-comer	N/A	N/A
	• Number of hydrants per floor	N/A	N/A
	• Hose Box	N/A	N/A
12.	Yard Hydrants		
	• Total number of hydrants	N/A	N/A
	• Hose Box	N/A	N/A
13.	Pumping Arrangements		
	• Ground Level	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A
	➤ Head of Main pump	N/A	N/A
	➤ Number of main pumps	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A
	➤ Jockey pump head	N/A	N/A
	➤ Standby Pump out put	N/A	N/A
	➤ Standby Pump Head	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A
	• Pump House Access	N/A	N/A
	• Terrace level	450 LPM	Provided
	• Discharge of pump	40 m	Provided
	• Head of the pump	Required	Provided
	• Power Supply	Required	Provided
	• Auto Starting of pump	Required	Provided
14.	Captive Water Storage for fire fighting		
	• Underground tank capacity	N/A	N/A
	➤ Draw-off connection	N/A	N/A
	➤ Fire service inlet	N/A	N/A
	➤ Access to tank	N/A	N/A
	• Overhead Tank capacity	10,000 ltrs	Provided
		Required	Provided
15.	Exit Signage.		
16.	Provision of Lifts.		
	• Pressurization of Lift Shaft	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A
	• Communication In lift Car	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A
	• Lift Signage	N/A	N/A
17.	Standby power supply		
		N/A	Provided
18.	Refuge Area.		
	➤ Total Area	N/A	N/A
	➤ Location	N/A	N/A

N/A

File

(Handwritten marks)

N/22

Fire Control Room			
• Detector System Panel	N/A	N/A	N/A
• Flow Switch Panel	N/A	N/A	N/A
• PA System Panel	N/A	N/A	N/A
• Battery backup	N/A	N/A	N/A
• Building Floor Plans	N/A	N/A	N/A
Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F6/DFS/MS/School/2020/SZ/303 dated 24/08/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R K Yadav
27/07/2023

Signature of Inspecting Officer
Name:- R.K.Yadav
Designation:- Asstt. Divisional Officer

D.O. (South West)

[Signature]
08/2/23

[Signature]
20/7/2023

[Signature]
31/9/22

ADD/R. K. Y

FT letter is put up for sign please

DIRECTOR *[Signature]*
11/0/23

R K Yadav
02/8/2023

n