



No.F6/DFS/MS/EH/NDZ/2023/247

Dated: 07/08/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Show Sha Baazi Cafe and Restaurant located at G 80 Third floor, Main Vikas Marg, Delhi-110092, running at Third floor only in a building comprised of Basement + Ground + 3 Upper floor, owned/occupied Show Sha Baazi Café have complied with the Fire Prevention and Fire Safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 02/08/2023 in the presence of Mr. Hardik Goyal (Owner) and found that the building/premises is fit for occupancy class "Assembly" (Group D) Eating House / Bar (Restaurant at Third floor only) and valid up to 31/03/2026 (Three years) in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued 07/08/2023 at New Delhi by.

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

**Copy to: -**

1. Show Sha Baazi Cafe and Restaurant located at G 80 Third floor, Main Vikas Marg, Delhi-110092.
2. Joint Commissioner of police (Lic.), 1st Floor, P.S Defence Colony, New Delhi-24 w.r.t.-MHA portal ID-2023072713461 dated 27/07/2023.

**Condition for the validity of fire safety certificate**

- 1 Lift around the staircase will remain sealed with proper brick wall and plaster.
- 2 All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 3 Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 4 The trained fire fighting staff should be available round the clock.
- 5 Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 6 This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 7 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
- 8 The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 9 Basement shall be used strictly as per Building By-Laws 1983.
- 10 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

**PINSPECTION REPORT**

1	Name & address of the building	Show Sha Baazi Cafe and Restaurant located at G 80 Third floor, Main Vikas Marg, Delhi-110092.		
2	Building is comprised of	Basement + Ground + 3 Upper floor ( <b>Restaurant is running on 3<sup>rd</sup> floor of the building</b> )		
3	Type of occupancy	Assembly (Eating House & Bar)		
4	Type of case	New Case		
5	Details of previous FSC	Nil		
6	Fire safety direction letter no.	NBC Part-IV		
7	Date of inspection	02.08.2023		
8	Name of the inspecting officers	A.K.Jaiswal, DO (E/D) & Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer From the building side	Mr. Hardik Goyal (Owner)		
10	Year of construction	2005		
11	Applicant's letter no.	Application No. I.D -2023072713461 dated 27/07/2023		
S. No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements	Provide at site	Remarks
1	Access to Building	NBC		MR/NMR
A	Road width	09 mtrs	30 mtr	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal roads	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
A	No. of staircase:			
a)	Upper floor	02 nos.	02 nos.	MR
b)	Basements	N/A	N/A	N/A
B	Width of the staircase:			
a)	Upper floors	1.50 mtrs.	1.50 mtrs & 1.50 mtrs	MR
b)	Basements	N/A	N/A	N/A
C	Protection of Exits			
a)	Fire check door	Required	Provided	MR
b)	Pressurization	N/A	N/A	N/A
D	No. of continuous staircase to terrace:	01 no.	01 no.	MR
E	Width of the corridor	N/A	N/A	N/A
F	Door size	1.50 mtrs x2	1.50 mtrs x2	MR
3	Compartmentation:			
A	Fire check doors	02 nos.	02 nos.	MR
B	Sealing of horizontal & vertical opening	N/A	N/A	N/A
C	Fire rating of shaft doors	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	Smoke management System:			
A	Basements	N/A	N/A	N/A
B	Upper floors	12 a/c per hour	Ventilated	MR
5	Fire extinguishers			
A	Total numbers	04 nos.	06 nos.	MR
B	Types	ISI marked ABC/CO <sub>2</sub>	Provided	MR
C	ISI marking	ISI marked	Provided	MR

① A 50,

Show Sha Baazi Cafe and Restaurant located at G 80 Third floor, Main Vikas Marg, Delhi-110092.

<b>6</b>	<b>First Aid Hose Reel</b>			
<b>A</b>	Total no. at each floor	01 no.	01 no.	MR
<b>B</b>	Length of hose reel	30 mtrs	30 mtrs	MR
<b>C</b>	Nozzle diameter	5 mm	5 mm	MR
<b>7</b>	<b>Automatic Fire Detection and Alarm System</b>			
<b>A</b>	Type of detectors	Heat & Smoke	Provided	MR
<b>B</b>	Location of main Panel	3 <sup>rd</sup> floor	Provided	MR
<b>C</b>	Location of repeater panel	N/A	N/A	N/A
<b>D</b>	Alternate power source	Required	Provided	MR
<b>E</b>	Hooter's location	Staircase	Provided	MR
<b>8</b>	MOEFA	Required	Provided	MR
<b>9</b>	Public Address System	Required	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System</b>			
<b>A</b>	Basement	N/A	N/A	N/A
<b>B</b>	Upper floor	N/A	N/A	N/A
<b>C</b>	Sprinklers above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
<b>A</b>	Size of the riser/down comer	100 mm	100 mm	MR
<b>B</b>	No. of hydrants per floor	01 no.	01 no.	MR
<b>C</b>	Hose box	01 no.	01 no.	MR
<b>12</b>	<b>Yard Hydrants</b>			
<b>A</b>	Total no. of hydrants	N/A	N/A	N/A
<b>B</b>	Hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements</b>			
<b>A</b>	Ground Level			MR
	a) Discharge of main pump	2280 LPM	2280 LPM	MR
	b) Head of Main Pump	60 mtrs	60 mtrs	MR
	c) Number of Main Pump	01 no.	01 no.	MR
	d) Jockey Pump out put	180 LPM	180 LPM	MR
	e) Jockey Pump Head	60 mtrs	60 mtrs	MR
	f) Standby Pump out put	2280 LPM	2280 LPM	MR
	g) Standby Pump Head	60 mtrs	60 mtrs	MR
	h) Auto Stating/ Manual	Required	Provided	MR
	i) Pump House Access	Required	Provided	MR
<b>B</b>	Terrace Level			MR
	a) Discharge of Pump	450 LPM	450 LPM	MR
	b) Head of terrace pump	40 mtrs	40 mtrs	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
<b>14</b>	<b>Captive Water Storage for Fire Fighting.</b>			
<b>A</b>	Underground tank capacity	1,00,000 ltrs	1,00,000 ltrs	MR
<b>B</b>	Draw off connection	N/A	N/A	N/A
<b>C</b>	Fire Service Inlet	N/A	N/A	N/A
<b>E</b>	Access to tank	Required	Provided	MR
<b>D</b>	Overhead tank capacity	10,000 ltrs	10,000 ltrs	MR
<b>15</b>	Exit Signage	Required	Provided	MR
<b>16</b>	<b>Provision of lift</b>			
<b>A</b>	Pressurization of lift shaft	N/A	N/A	N/A
<b>B</b>	Pressurization of lift lobby	N/A	N/A	N/A
<b>C</b>	Communication in lift car	Required	Provided	MR
<b>D</b>	Fireman switch	Required	Provided	MR
<b>E</b>	Lift signage	Required	Provided	MR
<b>17</b>	Standby Power Supply	Required	Provided	MR

⑩

X

CO /

S h a n a	18 Refuge Area				
	A	location	N/A	N/A	N/A
	B	Total area	N/A	N/A	N/A
S h a n a B a z i	19 Fire Control Room				
	A	Fire Detection System panel	N/A	N/A	N/A
	B	Flow switch panel	N/A	N/A	N/A
	C	P A system panel	N/A	N/A	N/A
	D	Battery backup	N/A	N/A	N/A
	E	Building floor plan	N/A	N/A	N/A
S h a n a B a z i	20 Special Fire Protection for special risk if any				
	A	Special Fire Protection system for Protection of Special Risk, if any:	NA	NA	NA

Note:- Applicant has given an undertaking that lift has been closed at each floor and they will not use lift in any case (undertaking at C-21 and photograph at C-22 to C-25)

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The shortcomings issued vide letter no. F6/DFS/MS/EH/2023/NDZ/261 dated 19.05.2023 by this department have been rectified by the management.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to grant Fire Safety Certificate under Rules 37 of Delhi Fire Service Rules 2010.

*A.K. Jaiswal*  
02/08/2023

Signature of the Inspecting Officer  
Name: A.K. Jaiswal  
Designation: DO (FD)

*Yashwant Singh Meena*  
02/08/2023

Signature of the Inspecting Officer  
Name: Yashwant Singh Meena  
Designation: ADO (L.N)

~~Dy.CFO (NDZ)~~

*ADP*  
02/08/23

~~C.F.O.~~

*ADP*  
31/8/2023

~~Director~~

*ADP*  
7/8/23

FI PLS

~~DI K/ADP~~

F.T. letter is put up for sig. pl.

*ADP*  
07/08/23

~~UP Director~~  
7/8/23

Uploaded  
02/8/23