



No.F6/DFS/MS/School/NDZ/2023/533

Dated: 04/08/2023

FIRE SAFETY CERTIFICATE

Certified that the **Vishwa Bharti Public School, C-4, Ganga Vihar, Delhi-110094**, comprised of Ground + 02 Upper floors only, owned / occupied by **Vishwa Bharti Public School**, was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2018/NDZ/1266 dated 31/05/2018. The school building was re-inspected by the officer concerned of this department on 25/07/2023 in presence of Sh. Vipin Sharma (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Act 2007, Rules 2010 and that the building is fit for occupancy class "Educational" (Group-B) with effect from 04/08/2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 04/08/2023 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Director of Education, B- Block, Yamuna Vihar, Delhi-110053.
2. The Manager, Vishwa Bharti Public School, C-4, Ganga Vihar, Delhi-110094.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

| | | | | |
|-------------|---|---|-------------------------|-----------------------|
| 1 | Name & address of the building | Vishwa Bharti Public School, located at C-4, Ganga Vihar, Delhi-110094. | | |
| 2 | Building is comprised of | Ground + 02 upper floors only. | | |
| 3 | Type of occupancy | Educational Building | | |
| 4 | Type of case | Renewal | | |
| 5 | Details of previous FSC | F6/DFS/MS/School/2018/NDZ/1266 dated-31/05/2018 | | |
| 6 | Fire safety directives letter no. | NBC Part IV | | |
| 7 | Date of inspection | 25/07/2023 | | |
| 8 | Name of the inspecting officers | Yashwant Singh Meena ADO (L.N) | | |
| 9 | Name of the designation of officer from the building side | Mr. Vipin Sharma (Manager) | | |
| 10 | Year of construction | 2001 | | |
| 11 | Applicant's letter no. | Outdoor Diary No-3735 Date-13.07.2023 | | |
| S.No | Minimum standard of fire prevention and fire safety U/R 33 | NBC Part IV Requirement | Provided at site | Remarks MR/NMR |
| 1 | Access to Building: | | | |
| A | Road width | 6.0 mtrs. | 9.0 mtrs. | MR |
| B | Gate width | N/A | N/A | N/A |
| C | Width of internal road | N/A | N/A | N/A |
| 2 | Number, Width, Type and Arrangement of Exits: | | | |
| A | Number of staircases | | | |
| a | Upper floor | 01 no. | 02 nos. | MR |
| b | Basement | N/A | N/A | N/A |
| B | Width of staircases | | | |
| a | Upper floor | 1.50 mtrs. | 0.91mtr & 1.0 mtrs. | MR |
| b | Basement | N/A | N/A | N/A |
| C | Protection of exits | | | |
| a | Fire check door | N/A | N/A | N/A |
| b | Pressurization | N/A | N/A | N/A |
| D | No. of continuous staircases to terrace | 01 no. | 01 no. | MR |
| E | Width of corridor | 1.50 mtrs. | 1.50 mtrs. | MR |
| F | Door size | 1.0 mtrs. | 1.0 mtrs. | MR |
| 3 | Compartmentation: | | | |
| A | Fire check door | NA | NA | NA |
| B | Sealing of electrical shafts | N/A | N/A | N/A |
| C | Fire rating of shaft door | N/A | N/A | N/A |
| D | Water curtain | N/A | N/A | N/A |
| E | Fire dampers | N/A | N/A | N/A |
| 4 | Smoke Management System: | | | |
| A | Basement | N/A | N/A | N/A |
| B | Upper floor | N/A | N/A | N/A |

① d

N/12

| | | | | |
|--|--------------------------------|-----------------------|-----------------------|-----|
| 5. Fire Extinguisher: | | | | |
| A | Total numbers | 06 nos. | 06 nos. | MR |
| B | Types | ABC & CO ₂ | ABC & CO ₂ | MR |
| C | ISI marking | ISI Marked | Provided | MR |
| 6 First-Aid-Hose Reel: | | | | |
| A | Total numbers of each floor | 01 no. | 01 no. ✓ | MR |
| B | Length of hose reel hose | 30 mtrs | 30 mtrs | MR |
| C | Nozzle diameter | 05 mm | 05 mm | MR |
| 7 Automatic Fire Detection and Alarming System: | | | | |
| A | Type of detectors | N/A | N/A | N/A |
| B | Location of main panel | N/A | N/A | N/A |
| C | Location of repeater panel | N/A | N/A | N/A |
| D | Alternate source of power | N/A | N/A | N/A |
| E | Hooters | N/A | N/A | N/A |
| 8 | MOEFA: | N/A | N/A | N/A |
| 9 | Public Address System: | N/A | N/A | N/A |
| 10 Automatic Sprinkler System: | | | | |
| A | Basement | N/A | N/A | N/A |
| B | Upper floor | N/A | N/A | N/A |
| C | Sprinkler above false ceiling | N/A | N/A | N/A |
| 11 Internal Hydrants: | | | | |
| A | Size of riser/down-comer | N/A | N/A | N/A |
| B | Number of hydrants per floor | N/A | N/A | N/A |
| C | Hose box | N/A | N/A | N/A |
| 12 Yard Hydrants: | | | | |
| A | Total number of hydrants | N/A | N/A | N/A |
| B | Hose box | N/A | N/A | N/A |
| 13 Pumping Arrangements: | | | | |
| 1 Ground level | | | | |
| A | Discharge of main pump | N/A | N/A | N/A |
| B | Head of main pump | N/A | N/A | N/A |
| C | Number of main pumps | N/A | N/A | N/A |
| D | Jockey pump out put | N/A | N/A | N/A |
| E | Jockey pump head | N/A | N/A | N/A |
| F | Standby pump out put | N/A | N/A | N/A |
| G | Standby pump head | N/A | N/A | N/A |
| H | Auto starting /manual stopping | N/A | N/A | N/A |
| I | Pump house access | N/A | N/A | N/A |
| 2 Terrace Level | | | | |
| A | Discharge of pump | 450 LPM | 450 LPM ✓ | MR |
| B | Head of the pump | 40 mtrs | 40 mtrs. ✓ | MR |
| C | Power supply | Required | Provided | MR |
| D | Auto starting of pump | Required | Provided | MR |


Vishwa Bharti Public school, C-4, Ganga Vihar, Delhi-110094.

W ✱ W1

| | | | | |
|-----------|---|--------------|----------------|-----|
| 14 | Captive Water Storage for Fire Fighting: | | | |
| A | Underground tank capacity | N/A | N/A | N/A |
| B | Draw-off connection | N/A | N/A | N/A |
| C | Fire service inlet | N/A | N/A | N/A |
| D | Access to tank | N/A | N/A | N/A |
| E | Overhead tank capacity | 10,000 ltrs. | 10,000 ltrs. ✓ | MR |
| 15 | Exit Signage: | Required | Provided | MR |
| 16 | Provision of Lifts: | | | |
| A | Pressurization of lift shaft | N/A | N/A | N/A |
| B | Pressurization of lift lobby | N/A | N/A | N/A |
| C | Communication in lift car | N/A | N/A | N/A |
| D | Firemen's grounding switch | N/A | N/A | N/A |
| E | Lift signage | N/A | N/A | N/A |
| 17 | Standby Power Supply: | N/A | N/A | N/A |
| 18 | Refuge Area: | | | |
| A | Total area | N/A | N/A | N/A |
| B | Location | N/A | N/A | N/A |
| 19 | Fire Control Room: | | | |
| A | Detector system panel | N/A | N/A | N/A |
| B | Flow switch panel | N/A | N/A | N/A |
| C | PA system panel | N/A | N/A | N/A |
| D | Battery backup | N/A | N/A | N/A |
| E | Building floor plans | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N/A | N/A | N/A |


The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in rule 33 of Delhi Fire Service Act 2007, Rules 2010, the FSC issued vide letter no. F6/DFS/MS/School/2018/NDZ/1266 dated-31/05/2018 is recommended to be renewed.


 28/7/2023
 Signature of the Inspecting Officer
 Name Yashwant Singh Meena
 Designation ADO (L.N)


DO (E.D)


DFA RL


 31/7/223

DY- CFO / (NDZ)


 01/08/23

C.F.O

 28/07/2023

Director / 
 28/07/23



P.T.O