

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F-6/DFS/MS/SZ/2023/EH/263

Dated: 11/08/2023

FIRE SAFETY CERTIFICATE

Certified that the M/S Fire 'N' Ice Restaurant Located at Pankaj Arcade – III, Shop No. 310 3rd floor, DDA Market, Sector – 10, Dwarka, New Delhi, is running at 3rd floor in a building comprised of Ground + 3 Upper floor was issued FSC by this department vide letter no. F6/DFS/MS/EH/2020/SZ/110, dated 21/07/2020. The premises was re – inspected by the officer concerned of this department on 02/08/2023 in the presence of Sh. Sekhar Patel (Manager) and found that the premises have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010, and that the building is fit for occupancy class “ Assembly” Group D (3rd floor) with effect from 11/08/2023 to 31/03/2026 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/08/2023 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
o/c

Copy to:

1. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, N Delhi.
2. The Manager, M/S Fire 'N' Ice Restaurant Located at Pankaj Arcade – III, 3rd floor, DDA Market, Sector – 10, Dwarka, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: M/S Fire 'N' Ice Restaurant Located at Pankaj Arcade - III, 3rd floor, DDA Market, Sector - 10, Dwarka, New Delhi.
2. Type of Occupancy : Class-D (Assembly)(At 3rd Floor in a building comprised of G + 3 UFs)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2020/SZ/110, dated 21/07/20
5. Fire Safety directives L. No. : F6/MS/DFS/GH/2005/711, dated 01/04/05
6. Date of inspection : 02/08/2023
7. Name of the Inspecting Officer ; ADO (DWK)
8. Name and designation of Officer from the building side : Sh. Sekhar Patel (Manager)
9. Year of Construction. : 2002
10. Applicant's letter No. : 2022033004621, dated 24/07/2023


S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/17, N/18 & N/19	Provided at site	Remarks MR/NMR
1.	Access of building	06 mtrs	Provided	MR
	• Road width	NA	NA	NA
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	g. Number of staircases	01 No.	Provided	MR
	• Upper floors	NA	NA	NA
	• Basements			
	h. Width of staircases	1.25m	1.17M	MR(Being old case)
	• Upper floors	NA	NA	NA
	• Basements			
	i. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	Required	01	MR
	j. No of continuous staircase to terrace	NA	NA	NA
	k. Width Of Corridor	2m	2 mtr & 1m	MR
	l. Door Size			
3.	Compartmentation	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System	NA	NA	NA
	• Basements	12 a/c per hour	Exhaust fans	MR
	• Upper floors			

5.	Fire Extinguishers				
	• Total numbers	04 nos.	Provided		MR
	• Types	ABC, CO2	Provided		MR
	• IS marking	ISI marked	Provided		MR
6.	First – Aid Hose Reel				
	• Total numbers on each floor	01 No	Provided		MR
	• Length of hose reel hose	30 m	Provided		MR
	• Nozzle diameter	5 mm	Provided		MR
7.	Automatic fire detection and alarming system				
	• Type of detectors	NA	NA	NA	
	• Location of Main Panel	NA	NA	NA	
	• Location of Repeater Panel	NA	NA	NA	
	• Alternate source of power	NA	NA	NA	
	• Hooters' Location				
8.	MOEFA		Required	Provided	MR
9.	Public Address System		NA	NA	NA
10.	Automatic Sprinkler System				
	• Basements	NA	NA	NA	
	• Upper Floor	Required	Provided in entire floor		MR
	• Sprinkler above false ceiling	NA	NA	NA	
11.	Internal Hydrants:				
	• Size of riser/down- comer	NA	NA	NA	
	• Number of hydrants per floor	NA	NA	NA	
	• Hose Box	NA	NA	NA	
12.	Yard Hydrants				
	• Total number of hydrants	NA	NA	NA	
	• Hose Box	NA	NA	NA	
13.	Pumping Arrangements:				
	• Ground Level	NA	NA	NA	
	• Discharge of main pump	NA	NA	NA	
	➤ Head of main pump	NA	NA	NA	
	➤ Number of main pumps	NA	NA	NA	
	➤ Jockey pump out put	NA	NA	NA	
	➤ Jockey pump head	NA	NA	NA	
	➤ Standby Pump out put	NA	NA	NA	
	➤ Standby Pump Head	NA	NA	NA	
	➤ Auto Staring/Manual stopping	NA	NA	NA	
	➤ Pump House Access	NA	NA	NA	
	• Terrace level	450 lpm, 180 lpm		Provided	MR
	➤ Discharge of pump	30 m	Provided		MR
	➤ Head of the pump	Required	Provided		MR
	➤ Power supply	Required	Provided		MR
	➤ Auto starting of pump	Required	Provided		MR
14.	Captive water Storage for fire fighting:				
	• Under ground tank capacity	NA	NA	NA	
	➤ Draw off connection	NA	NA	NA	
	➤ Fire service inlet	NA	NA	NA	
	➤ Access to tank	10, 000 litres	Provided		MR
	• Overhead Tank capacity	Required	Provided		MR
15	Exit Signage		Required	Provided	MR


16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panel	MR


The fire protection systems provided in the building were test checked and found functional at the time of inspection.


In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/EH/2020/SZ/110, dated 21/07/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended



 Signature of the Inspecting Officer
 Name UdaiVir Singh
 Designation ADO/DWK


 5/8/23


 9/8/2023


 9/8/23



Sir FY letter is put up for sig ple 


 11/10/23