



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SZ/2021/ 378

Dated: 09/08/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Safdarjung Service Station (Retail Outlet of HPCL), Safdarjung Road, New Delhi-110003, comprised of Ground Floor only owned / occupied by M/s Safdarjung Service Station, was issued Fire Safety Certificate vide letter No. F6/DFS/MS/2020/SZ/452 dated 03/11/2020. The premises was re-inspected by the officer concerned of Fire Service on 18.07.2023 in the presence of Sh. Harish Chander Bhadula (Manager) and found that the said premises have deemed complied with the fire safety requirements in accordance with 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Mixed Occupancy (Petrol Pump & Service Station)" with effect from 09/08/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/08/2023 at New Delhi by.


(ATUL GARG)
DIRECTOR
Delhi Fire Service

Copy to :-

1. M/s Safdarjung Service Station (Retail Outlet of HPCL), Safdarjung Road, New Delhi-110003.
2. The Medical Officer Health, NDMC, Palika Kendar, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

N-2)

INSPECTION REPORT

1. Name & address of the building : **M/s Safdarjung Service Station (Retail Outlet of HPCL), Safdarjung Road, New Delhi-110003.**
2. Type of Occupancy : Mixed Occupancy (Petrol Pump & Service Station)
3. Building Comprised of : Ground floor only.
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2020/SZ/452 dated 03/11/2020
6. Fire Safety directives Letter No. : Nil
7. Date of inspection : 18/07/2023
8. Name of the Inspecting Officer : A.D.O. (S.J.) Santosh Kumar
9. Name and designation of Officer
from the building side : Sh. Harish Chander Bhadula (Manager)
10. Year of construction : 1952
11. Applicant's letter revived through Outdoor Dairy no-3724 dated 12/07/2023

S. No	Minimum standards on fire prevention and fire safety U/R 33	Requirements/ Existing Fire Protection	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	12m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA		
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 ACPH	NA	NA
	• Upper floors	12 ACPH	NA	NA
5.	Fire Extinguishers			
	• Total numbers	10 nos.	25 nos.	MR
	• Types	ISI marked DCP/CO ₂	ABC,DCP/C O ₂	MR
	• ISI marking	ISI marked	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	NA	NA	NA
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;		NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2020/SZ/452 dated 03/11/2020 renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

Santosh Kumar
19.07.23

Signature of the Inspecting Officer
Name : Santosh Kumar
Designation : A.D.O. (S.J.)

DD (S/Genl)

meml

21/7/23

what is area of Service Station (i.e. covered area)

CPD Mugh
20/7/2023

Director DO (Genl)

meml

ADD (S.J.)

21/7/23

covered area is 135.36 sqm. Resubmitted for your approval please.

Santosh Kumar
25.07.23 P.F.O