



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001




No. F6/DFS/MS/2023/Incl./ 381

Dated: 09/08/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Shanti Steel Pvt. Ltd. located at Plot No- 03, SSI, Co-op, Industrial Estate, G.T. Karnal Road, Delhi-110033 comprised of Basement, Ground, Mezzanine & first floor only owned/occupied by M/s Shanti Steel Pvt. Ltd. issued FSC by this department vide this office letter no. F6/MS/DFS/2020/WZ/272 dated 27.07.2020. The premise was re-inspection by the officer concerned of this department on 26.06.2023 in presence of Sh. Sharabjeet Singh (Maintenance Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rules 33 of the Delhi Fire Service Rules, 2010 and building premises is fit for occupancy class G-2 "Industrial building" with effect from 09/08/2023..... for a period of Valid up to 31.03.2026, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/08/2023..... at New Delhi by


(Atul Garg)
Director
Ph:-011-23414000
s e e

Copy to :-

1. The Dy. Commissioner of Factory licensing, DMC 3rd, Floor, Civic Centre Minto Road, Delhi-110002
2. The Manager, M/s Shanti Steel Pvt. Ltd. located at Plot No- 03, SSI, Co-op, Industrial Estate, G.T. Karnal Road, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M/s Shanti Steel Pvt. Ltd. at Plot No. 03, SSI, Co-op Industrial Estate, G.T. Karnal, Road, Delhi-110033.
2. Type of Occupancy : Industrial Building
3. Type of Case : Renewal
4. Composition of building : Basement, Ground, Mezzanine & first floor only
5. Details of previous NOC : F6/DFS/MS/2020/WZ/272 Dated: 27.07.2020
6. Fire Safety directives letter No : F6/DFS/MS/BP/93/1865 Dated: 10.11.1993
7. Date of inspection : 26.06.2023
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Sharabjeet Singh (Maintenance Manager)
10. Year of Construction : --
11. Applicant's letter No. : Letter No. Nil Dated: 21.06.2023 & DFS Dairy No.3124 Dated-23.06.2023

S.no.	Minimum Standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	20m	MR (old case)
	• Gate width	05m	05m	MR (old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	01	MR (old case)
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	1.20m	1.20m	MR (old case)
	• Basements	1.20m	01m x2	MR(old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR (old case)
	e. Width of Corridor	1.20m	Provided	MR
f. Door Size	1.50m	Provided	MR	
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	18nos	19nos	MR

/s/

	<ul style="list-style-type: none"> Types ISI marking 	ABC/CO2	ABC-17/Co2-02	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	Required,06	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30m	30m	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8	MOEFA	NA	Provided	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100mm x2	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	02	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	02	Provided	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	02	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	02	Provided	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	450 LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of Main pump 	40m	40m	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps 	01	01	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 			
	<ul style="list-style-type: none"> ➤ Jockey pump head 	180 LPM	180 LPM	MR
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	40m	40m	MR
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of the pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Power Supply 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	NA	NA	NA
14	Captive Water Storage for fire fighting.			

Handwritten signature or initials at the bottom center of the page.

	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	1,00,000 LTR	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		20,000 LTR	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts. One open goods lift is provided			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication In lift Car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift Signage 	N/A	N/A	N/A
17	Standby power supply	N A	Provided	NA
18	Refuge Area.			
	<ul style="list-style-type: none"> Total Area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location 	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Flow Switch Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> PA System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Batter backup 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked and found in working order at the time of inspection. The observations/ shortcomings issued and communicated vide this department letter of even no. F6/DFS/MS/2023/Indl./1228 dated 13.06.2023 have been compiled by the management.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. F6/DFS/MS/2020/WZ/272 dated 27.07.2020 under rule 37 of the Delhi Fire Service Rules 2010.

D.B. Mukharjee
Divisional Officer (NWD)

epo

3/8/2023

ADO (NWD/RN)

why this file is so late?

Signature of the Inspecting Officer

Name :- C.L. Meena

Designation:- Asst. Div. Officer (RN)

Conf. P.T.O.