



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2023/SZ/540

Dated: 08/08/2023

FIRE SAFETY CERTIFICATE

Certified that The Indian School located at Josip Broz Tito Marg, Near Moolchand Flyover, New Delhi-110049, comprised of Basement, Ground plus three upper floor owned/occupied by The Indian School has already been issued Fire Safety Certificate Vide letter No. F.6/DFS/MS/School/2020/SZ/238 dated 20/07/2020. The premises was re-inspected by the officer concerned of this department on 06/07/2023 in the presence of Sh. Brijesh Kumar Singh Asstt. (Admin officer) of the school and found that the said school premises have deemed compiled with the fire prevention and fire safety requirement in accordance with rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy Class "Educational" Group -B(school) with effect from 08/08/2023 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 08/08/2023 at New Delhi by


(ATUL GARG)
DIRECTOR
Delhi fire Service

Copy to :-

1. The Principal, The Indian School located at Josip Broz Tito Marg, Near Moolchand Flyover, New Delhi- 110049.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	The Indian School, Josip Broz Tito Marg, Near Moolchand Flyover, New Delhi-110049		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Basement (area-1563.07m ²), Ground + 03 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2020/SZ/238 dated 20-07-2020		
6	Fire Safety Directives Letter No	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011		
7	Date of Inspection	06-07-2023		
8	Name of the Inspecting Officers	DO(SD) M.K. Sharma & A.D.O. (S.J.) Santosh Kumar		
9	Name & Designation of Officers from the building side	Sh. Brijesh Kumar Singh (Asstt. Admin officer)		
10	Year of construction	Not Known	Case referred through SDMC Vide letter No D/09/AE(B)-II/CNZ/20 dt 01/06/2020	
11	Applicant letter No.	Outdoor Diary No. 1379 dated 27/04/2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 mtr	Provided	MR
	• Gate width	4.5 mtr	4.90m, 5.86m, 4.62m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	03 Nos	Provided	MR
	➤ Basement floor.	03 Nos	Provided	MR
	b) Width of Staircase			
	➤ Upper floors	1.5 mtr	1.5 mtr each	MR
	➤ Basement floor	1.5 mtr	1.5 mtr each	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Two	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	Required	1.10m	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fans	-NA-
	• Upper floors	12 ACPH	Provided	-NA-
5.	Fire Extinguishers.			
	• Total numbers	Required	45 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR

186

6.	First Aid Hose Reels.			
	• Total numbers on each floor.	Two	Provided (3 Nos.)	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8.	MOEFA	NA	Provided	MR
9.	Public Address System	NA	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	NA	100mm	MR
	• Number of Hydrant per floor	NA	Two	MR
	• Hose box.	NA	Two	MR
12.	Yard Hydrants.			
	• Total number of hydrants.	-NA-	06 Nos	-NA-
	• Hose box.	-NA-	06 Nos	-NA-
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	NA	220 LPM	MR
	➤ Head of main pump.	NA	40 mtr	MR
	➤ Number of main pumps.	NA	One	MR
	➤ Jockey Pump output.	NA	-NA-	-NA-
	➤ Jockey Pump head.	NA	-NA-	-NA-
	➤ Standby Pump output.	NA	-NA-	-NA-
	➤ Standby Pump head.	NA	-NA-	-NA-
	➤ Auto Starting/Manual Stopping.	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump.	900 LPM	900 LPM	MR
	➤ Head of pump.	40 mtr	40 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	• Underground tank capacity.	NA	40,000 Ltr	MR
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	15,000 Ltr	15,000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-

SP

17.	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	Required	Provided	MR
	• Battery backup.	Required	Provided	MR
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	02 ABC fire extinguishers provided near electric panels.	MR

The Indian School at Josip Broz Tito Marg, Near Moolchand Flyover, New Delhi-110049

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2020/SZ/238 dated 20/07/2020, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer
Name : Manoj Kumar Sharma
Designation: DO(SD)

Signature of the Inspecting Officer
Name : Santosh Kumar
Designation : A.D.O. (S.J.)

Re-examine & put up inspection report accordingly

12/7/2023

DO (South)
12/7/23

Need full done. Submitted for approval
22/10/23

DO (South)
12/7/23