

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2023/250

Dated: 09/08/2023

FIRE SAFETY CERTIFICATE

Certified that the Timezone Entertainment Pvt. Ltd. Located at Shop No. 210, 211, 2nd Floor Plot No. 6 Sector-14 , Vegas Mall Dwarka Delhi-110075, in a building comprised of 4 tier Basement + Ground + 05 Upper Floors Fire Safety Certificate issued to mall vide letter No. F6/DFS/MS/SZ/2022/62 dated 09/12/2022 owned/ occupied by **Timezone Entertainment Pvt. Ltd** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned from this department on 02/08/2023 in the presence of Mr. Ashok Kumar Aman (Area Manager) and found that the said premises is fit for occupancy class "Assembly" Group D (Second Floor) with effect from 09/08/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/08/2023 at New Delhi by.


 (Atul Garg)
 Director
 Delhi Fire Service


Copy to:

1. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, N Delhi.
2. The Manager, Timezone Entertainment Pvt. Ltd. Located at Shop No. 210, 211, 2nd Floor Plot No. 6 Sector-14 , Vegas Mall Dwarka Delhi-110075

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

P/1
INSPECTION REPORT

1. Name & address of the building: Timezone Entertainment Pvt. Ltd. Located at Shop No. 210, 211, 2nd Floor Plot No. 6 Sector-14 , Vegas Mall Dwarka Delhi-110075.
2. Type of Occupancy : Class-D (Assembly)(At 2nd Floor in the Mall)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives L. No. :F6/DFS/MS/BP/2016/326 dated 16/12/2016 (issued to mall)
6. Date of inspection : 02-08-2023
7. Name of the Inspecting Officer ; DO/SW & ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Ashok Kumar Aman (Area Manager)
9. Year of Construction :
10. Applicant's letter No. :491-96/Joint. C.P/Lic.(Amst.) dated- 14/07/2023

Note- FSC issued to mall by this department vide letter No F6/DFS/MS/SZ/2022/62 dated 09/12/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12mtrs	Provided	MR
	• Gate width	06mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits(Common With Mall)			
	a. Number of staircases			
	• Upper floors	02 Nos.	02 Provided (by Mall)	MR
	• Basements	NA	12 Provided by Mall	NA
	b. Width of staircases			
	• Upper floors	2 mtr & 1,5m	Provided by Mall	MR
	• Basements	NA	Provided	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	2m & 1.5 M	Provided	MR
3.	Compartmentation(Common With Mall)			
	• Fire check door	Required	Provided by Mall	MR
	• Sealing of electrical shafts	Required	Provided by Mall	MR
	• Fire Rating of shaft door	Required	Provided by Mall	MR
	• Water Curtain	Required	Provided by Mall	MR
	• Fire Dampers	Required	Provided by Mall	MR

L
S

14. Captive water Storage for fire fighting: Common with Mall			
• Under ground tank capacity	NA	400000 l (By Mall)	NA
➤ Draw off connection	NA	Provided By Mall	NA
➤ Fire service inlet	NA	Provided By Mall	NA
➤ Access to tank	NA	Provided By Mall	NA
• Overhead Tank capacity	20, 000 litres	Provided By Mall	MR
15. Exit Signage	Required	Provided By Mall	MR
16. Provision of Lifts Common with Mall			
➤ Pressurization of Lift Shaft	NA	Provided By Mall	NA
➤ Pressurization of lift lobby	NA	Provided By Mall	NA
➤ Communication in lift Car	NA	Provided By Mall	NA
➤ Fireman's Grounding Switch	NA	Provided By Mall	NA
➤ Lift Signage	NA	Provided By Mall	NA
17. Standby power supply	Required	Provided By Mall	MR
18. Refuge Area			
➤ Total area	NA	Provided	NA
➤ Location	6 th & 9 th Floor	Provided	NA
19. Fire control room(Common with Mall)			
➤ Detector system panel	NA	Provided By Mall	NA
➤ Flow Switch Panel	NA	Provided By Mall	NA
➤ PA System Panel	NA	Provided By Mall	NA
➤ Battery backup	NA	Provided By Mall	NA
➤ Building Floor Plans	NA	Provided By Mall	NA
20. Special Fire Protection Systems for Protection of special Risks, if any;	NA	Provided By Mall	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010.

[Handwritten Signature]
21/8/23

Signature of the Inspecting Officer
Name: Sh. Vedpal
Designation: DO/SW

[Handwritten Signature]
21/8/23

Signature of the Inspecting Officer
Name: Udai Vir Singh
Designation: ADO/DWK

C/o (\$2)
[Handwritten Signature]
31/8/2023

[Handwritten Signature]
Director
A/O/SW

[Handwritten Signature]
A/O/SW

Sir FF letter is put up for sig of Mr

"DIRECTOR"
[Handwritten Signature]
A/O/SW

[Handwritten Signature]
21/8/23

[Handwritten Signature]