



C-29

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2023/NDZ/539

Dated: 08/08/2023

FIRE SAFETY CERTIFICATE

Certified that the Vishvamitra Sarvodaya Kanya Vidyalaya at Old Seema Puri, Delhi-110095 comprised of ground plus one upper floor (three separate blocks) owned/occupied by Vishvamitra Sarvodaya Kanya Vidyalaya was issued FSC vide letter No. F.6/DFS/MS/School/2020/NDZ/101 dated 04/03/2020. The school building was re-inspected by the officer concerned of this department on dated 20/07/2023 in the presence of Sh. Hari Kesh Singh, Estate Manager and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from 08/08/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on.....08/08/2023.....at New Delhi by


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

To,

The Principal
Vishvamitra Sarvodaya Kanya Vidyalaya at Old Seema Puri, Delhi-110095

Copy:-

The Dy. Director of Education,
B- Block, Yamuna Vihar, Delhi-110053

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

- N/11
- | | |
|-------------------------------------|---|
| 1. Name & address of the building | : Vishvamitra Sarvodya Kanya Vidyalaya
at Old Seema Puri, Delhi-110095 |
| 2. Building is comprised of | : G+ 1(Three Separate Blocks) |
| 3. Type of Occupancy | : Educational |
| 4. Type of Case | : Renewal |
| 5. Details of Previous NOC letter | : F.6/DFS/MS/School/2020/NDZ/101 dated
04/03/2020 |
| 6. Fire Safety directive letter No. | : F.16/Estate/CC/FS/2011/3298-3398 dt 01/03/2011 |
| 7. Date of Inspection | : 20/07/2023 |
| 8. Name of the Inspecting officers | : ADO Deepak Kumar |
| 9. Name and designation of Officer | : Sh. Hari Kesh Singh, Estate Manager |
| i. from the building side | : 1984 |
| 10. Year of Construction | : Email 1106021hos@gmail.com dated 16/05/2023 |
| 11. Applicant's letter No | |

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtr.	09 mtr.	MR
	• Gate width	4.50 mtr	4.50 mtr	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	1 Block - 02 nos. 2 Block - 01 no. 3 Block - 01 no.	1 Block - 02 nos. 2 Block - 01 no. 3 Block - 01 no.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor each block	1.50 mtr	1.50 mtr.	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 nos. in each block	01 nos. in each block	MR
	e. Width of Corridor	1.50 mtr. In each block	1.70 mtr. In each block	MR
	f. Door Size	01 mtr.	1.12 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	14 nos.	40 nos	MR
	• Types	ABC /CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	Provided	MR

N/12

06	First-Aid-Hose Reels			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump in each Block	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A

N/A

N/13

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule, the FSC issued vide letter No. F.6/DFS/MS/School/2020/NDZ/101 dated 04/03/2020 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Deepak
21/07/2023

Signature of the Inspecting Officer

Name :- Deepak Kumar

Designation :- A.D.O (Shd)

DO(ED)

DFA please.

By: CFO (NDZ)

DR
21/07/2023

Ring

24/07/23

Pl. spe about no. of blocks.

DO(ED)

DR
25/07/2023

Abol Shad.

Sir,
As per previous noting no. 2 there are three new blocks having 4 staircase and two old blocks having 3 staircase.