

C 65



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आजादी का  
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2023/ 547

Dated: 11/08/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **Anglo-Indian Public School** located at **B-330, Mansukh Singh Chauhan Marg, Sarita Vihar, New Delhi 110044**, comprised of **Ground + 02 Upper floor** owned/occupied by **Anglo-Indian Public School** has complied with the fire prevention and fire safety requirements in accordance with the circular no. 262 - 232 dated 17.01.2005 issued by the Directorate of Education and verified by the officer concerned of Delhi Fire Service on 03.04.2023 in the presence of Mrs. Neena Khera (Principal) and found that the school building (**Ground + 02 Upper floor**) is fit for occupancy of Group B "**Educational Building**" with effect from 11.08.2023... for a period of three years, subject to conditions printed below.

Issued on..11/08/2023.....at New Delhi by

  
(Arul Garg)  
Director  
Delhi Fire Service

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Principal, Anglo-Indian Public School located at B-330, Mansukh Singh Chauhan Marg, Sarita Vihar, New Delhi 110044.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT						
1	Name & address of the building	Anglo Indian Public School located at B-330, Mansukh Singh Chauhan Marg, Sarita Vihar, New Delhi-110044.				
2	Building is comprised of	Ground + 02 upper floors				
3	Type of occupancy	Group B- Educational building				
4	Type of case	New				
5	Details of previous FSC	Nil				
6	Fire safety direction letter no.	D.O.E Circular 262-232 dated-17/01/2005				
7	Date of inspection	02.08.2023				
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (M. Road)				
9	Name of the designation of officer from the building side	Mrs. Neena Khera (Principal)				
10	Year of construction	2000				
11	Applicant's letter no.	Outdoor Diary No.1932 dated 15.05.2023.				
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per D.O.E Circular dated 17.01.2005	Provided at site	Remarks MR/NMR		
1	<b>Access to Building:</b>					
	A	Road width	Accessibility	Provided	MR	
	B	Gate width	NA	NA	NA	
	C	Width of internal road	NA	NA	NA	
2	<b>Number, Width, Type and Arrangement of Exits:</b>					
	A	Number of staircases				
		a	Upper floor	2 nos.	2 nos.	MR
		b	Basement	NA	NA	NA
	B	Width of staircases				
		a	Upper floor	02 nos. of exits	1.50 mtrs. & 0.93 mtrs.	MR
		b	Basement	NA	NA	NA
	C	Protection of exits				
		a	Fire check door	NA	NA	NA
		b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace	1 no.	2 no.	MR	
	E	Width of corridor	1.5	Provided	MR	
	F	Door size	1.0 mtrs.	Provided	MR	
3	<b>Compartmentation:</b>					
	A	Fire check door	NA	NA	NA	
	B	Sealing of electrical shafts	NA	NA	NA	
	C	Fire rating of shaft door	NA	NA	NA	
	D	Water curtain	NA	NA	NA	
	E	Fire dampers	NA	NA	NA	
4	<b>Smoke Management System:</b>					
	A	Basement	NA	NA	NA	
	B	Upper floor	NA	NA	NA	

w

De

<b>5. Fire Extinguisher:</b>				
A	Total numbers	06 nos.	06 nos.	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
C	ISI marking	ISI Mark	Provided	MR
<b>6 First-Aid-Hose Reel:</b>				
A	Total numbers of each floor	01 no.	Provided	MR
B	Length of hose reel hose	30 mtrs	Provided	MR
C	Nozzle diameter	5 mm	Provided	MR
<b>7 Automatic Fire Detection and Alarming System:</b>				
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters	NA	NA	NA
8	<b>MOEFA:</b>	NA	NA	NA
9	<b>Public Address System:</b>	NA	NA	NA
<b>10 Automatic Sprinkler System:</b>				
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
<b>11 Internal Hydrants:</b>				
A	Size of riser/down-comer	NA	NA	NA
B	Number of hydrants per floor	NA	NA	NA
C	Hose box	NA	NA	NA
<b>12 Yard Hydrants:</b>				
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
<b>13 Pumping Arrangements:</b>				
<b>A Ground level</b>				
a)	Discharge of main pump	NA	NA	NA
b)	Head of main pump	NA	NA	NA
c)	Number of main pumps	NA	NA	NA
d)	Jockey pump out put	NA	NA	NA
e)	Jockey pump head	NA	NA	NA
f)	Standby pump out put	NA	NA	NA
g)	Standby pump head	NA	NA	NA
h)	Auto starting /manual stopping	NA	NA	NA
i)	Pump house access	NA	NA	NA
<b>B Terrace Level</b>				
a)	Discharge of pump	220 LPM	450 LPM	MR
b)	Head of the pump	40 mtrs	Provided	MR
c)	Power supply	Required	Provided	MR
d)	Auto starting of pump	Required	Provided	MR

14	<b>Captive Water Storage for Fire Fighting:</b>				
	A	Underground tank capacity	NA	NA	NA
	B	Draw-off connection	NA	NA	NA
	C	Fire service inlet	NA	NA	NA
	D	Access to tank	2,500 ltrs	10,000 ltrs	MR
	E	Overhead tank capacity	Required	Provided	MR
15	<b>Exit Signage:</b>				
16	<b>Provision of Lifts:</b>				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Firemen's grounding switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	<b>Standby Power Supply:</b>				
18	<b>Refuge Area:</b>				
	A	Total area	NA	NA	NA
	B	Location	NA	NA	NA
19	<b>Fire Control Room:</b>				
	A	Detector system panel	NA	NA	NA
	B	Flow switch panel	NA	NA	NA
	C	PA system panel	NA	NA	NA
	D	Battery backup	NA	NA	NA
	E	Building floor plans	NA	NA	NA
20	<b>Special Fire Protection systems for protection of special Risks, if any:</b>				
				NA	NA

**Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).**

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, it is recommended to issue FSC to the building under Rule 35(3) of the Delhi Fire Service Rules 2010.

*[Handwritten Signature]*  
03/8/23

Signature of the Inspecting Officer  
Name Rajesh Kumar Shukla  
Designation ADO (M. Road)

DO (SD)  
*[Handwritten Signature]*  
4/8/23

CFO *[Handwritten Signature]*  
7/8/2023

Director *[Handwritten Signature]*

*[Handwritten Signature]*  
ADO *[Handwritten Signature]*