

C-44

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6/DFS/MS/2023/EH/WZ/ 255

Dated: 11/08/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Bikanervala Foods Pvt. Ltd. Shop No.121, Gr. & FF, Rohini West Metro Station Complex Unity One, Rohini, Delhi-110085, comprised of building basement, ground and 05 upper floors owned/ occupied by M/s Bikanervala Foods Pvt. Ltd was granted NOC by this department vide letter no. F.6/DFS/MS/2020/126 dated 26.08.2020. The premises was re-inspected by the officers concerned of this department on 27.07.2023 in the presence of Sh. Suraj (Manager) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules,2010, and premises is fit for occupancy Class (Assembly) for (Eating House) for Shop no.121, Gr. & First floor with effect from 11-08-2023 for a period of 03 (Three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 11-08-2023..... at New Delhi by


(Atul Garg)
DIRECTOR
Ph: 011-234140000

Copy to:-

1. MHA Portal ID. 2023071412514 dated 14.07.2023

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Fire+Safety+Acts+and+R+ules/> <http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Forms.>

INSPECTION REPORT

1. Name & address of the building : M/s Bikanervala Foods Pvt. Ltd. Shop no 121, Gr. & FF, Rohini West Metro Station Complex Unity One, Rohini, Delhi 110085.
2. Type of Occupancy : Assembly (Restaurant located at Shop no 121 Gr. & First Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2020/126 dated 26.08.2020
5. Fire Safety directives letter No : NBC Part-4
6. Date of inspection : 27.07.2023
7. Name of the Inspecting Officers : ADO(Rohini)
8. Name and designation of officers from the building side : Sh. Suraj (Manager)
9. Year of Construction : 2014
10. Applicant's letter No. : Online application No.2023071412514 dated 14.07.2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building Unity One, MLCP, Rohini West Metro Station Complex, issued FSC vide letter No.F.6/DFS/MS/2022/454 dated 12.10.2022.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Restaurant within Mall	As Above	MR
2.	Number, Width, Type & Arrangement of Exits [Provided & Maintained by Mall management]			
	d. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
	e. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
	f. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
	d. No. of continuous staircases to terrace	Restaurant within Mall	As Above	NA
	e. Width of Corridor	Restaurant within Mall	As Above	NA
	f. Door Size	02 Exit	2m & 1.50m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
4.	Smoke Management System [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 ACPH	As Above	NA
		12 ACPH	Natural Ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	5 No's ABC/CO ₂ /W.CO ₂ ISI marked	5Nos 5/-/No's Provided	MR MR MR
6.	First-Aid Hose Reels [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One (Near to Restaurant) 30 m 5 mm	As Above As Above As Above	MR MR MR
7.	Automatic fire detection and alarming system [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Type of detectors 	NA	As Above	NA

	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	As Above	NA
		NA	As Above	NA
		NA	As Above	NA
		NA	As Above	NA
8.	MOEFA	Required	Provided	MR
		NA	As Above	NA
9.	Public Address System			
10.	Automatic Sprinkler System[Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Basement 	NA	As Above	NA
	<ul style="list-style-type: none"> Ground Floor 	NA	As Above	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	As Above	NA
11.	Internal Hydrants[Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100mm	As Above	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	One (near to Restaurant)	As Above	MR
	<ul style="list-style-type: none"> Hose Box 	One (near to Restaurant)	As Above	MR
12.	Yard Hydrants[Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13.	Pumping Arrangements[Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		[Provided & Maintained by Mall management]		
		NA	As Above	MR
		NA	As Above	MR
		Required	As Above	MR
		Required	As Above	MR
14.	Captive Water Storage for firefighting[Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	As Above	NA
		NA	As Above	NA
		NA	As Above	NA
		NA	As Above	NA
		NA	As Above	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.[Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	As Above	MR
18.	Refuge Area.[Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Total Area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room[Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

N/12

Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA
---	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of satisfactory compliance of the minimum standards on fire prevention and fire safety required under the rules and fire safety certificate issued vide letter of even no. F.6/DFS/MS/2020/126 dated 26.08.2020 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

[Signature]
28/7/23

Signature of the Inspecting Officer
Name: - A.K.Sharma
Designation:- ADO/Rohini

[Signature]
02/08/2023

D.B Mukherjee
(DO (NW))

[Signature]
3/8/2023

[Signature]
4/8/23

[Signature]
ADO/Roh

FF letter is put up for your
perusal and signature plz

[Signature]
Director
11/8/22

[Signature]
2/8

Uploaded
11/8/23
[Signature]