

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
 [Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/School/2023/555

Dated: 17/08/2023

FIRE SAFETY CERTIFICATE

Certified that the building of Jinvani Bharti Public School Located at Sector - 04, Dwarka, New Delhi - 110078, comprised of Basement + Ground + 3 Upper Floor was issued FSC vide Letter No. F6/DFS/MS/School/2020/SZ/319, dated 01/09/2020. The premises was re inspected by the officers concerned of this department on 07/08/2023 in the presence of Mrs. Preeti Jain (Principal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class-B "Educational" with effect from 17/08/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17.08.2023 at New Delhi by.

(Atul Garg)

Director

Delhi Fire Service

Copy to:

1. The Principal, Jinvani Bharti Public School, Sector - 04, Dwarka, New Delhi - 110078.
2. Directorate of Education Old Secretariat Delhi - 110054

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first Schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Jinvani Bharti Public School Located at Sector – 04, Dwarka, New Delhi – 110078.
2. Type of Occupancy : Educational (Ground+ 3 UFs & small basement)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2020/SZ/319, dated 01/09/2020
5. Fire Safety directives Letter No. : NBC Part-IV letter dated 24/11/2005
6. Date of inspection : 07/08/2023
7. Name of the Inspecting Officer :Sh. Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side: Mrs. Preeti Jain (Principal)
9. Year of Construction : 2006
10. Applicant's letter No. : Form J & K dated nil

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/11, N/12 & N/13	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 Nos.	Provided	MR
	• Basements	02 Nos.	Provided	MR
	b. Width of staircases			
	• Upper floors	1 No 1.7 M & 2 Nos. 1.3 M	Provided	MR(Being old case)
	• Basements	1.7 & 1.3 M	Provided	MR(Being old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	3 Nos.	Provided	MR
	e. Width Of Corridor	1.25 m	1.5 m Provided	MR
	f. Door Size	01 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c charge	Provided	MR
	• Upper floors	12 a/c charge	Natural ventilation	MR

h J.D.

N/15

5.	Fire Extinguishers				
	<ul style="list-style-type: none"> Total numbers Types IS marking 	Old case ABC or CO ₂ ISI marked	46 Nos.	MR	
			ABC & CO ₂	MR	
			ISI marked	MR	
6.	First – Aid Hose Reels				
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 nos	Provided	MR	
		30 mtr	Provided	MR	
		05 mm	Provided	MR	
7.	Automatic fire detection and alarming system				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
8.	MOEFA		NA	NA	NA
9.	Public Address System		Required	Provided	MR
10.	Automatic Sprinkler System				
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	Provided	NA	
		NA	NA	NA	
		NA	NA	NA	
11.	Internal Hydrants:				
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm	Provided	MR	
		02 Nos.	03 Nos.	MR	
		Required	Provided	MR	
12.	Yard Hydrants				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA	
		NA	NA	NA	
13.	Pumping Arrangements:				
	<ul style="list-style-type: none"> Ground Level Discharge of main pump > Head of main pump > Number of main pumps > Jockey pump out put > Jockey pump head > Standby Pump out put > Standby Pump Head > Auto staring/Manual stopping > Pump House Access Terrace level > Discharge of pump > Head of the pump > Power supply > Auto starting of pump 	NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		2x450 lpm & 1X 180 LPM	Provided	MR	
		40 mtr	Provided	MR	
		Required	Provided	MR	
	Required	Provided	MR		
14.	Captive water Storage for fire fighting:				
	<ul style="list-style-type: none"> Under ground tank capacity > Draw off connection > Fire service inlet > Access to tank Overhead Tank capacity 	50,000 ltr	50,000 ltr	MR	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		10,000 ltr	Provided	MR	
15	Exit Signage		Required	Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2020/SZ/319, dated 01/09/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Sign of Inspecting Officer

Name

Designation

~~12/04/23~~

Sign of Inspecting Officer
Name Uday Vir Singh
Designation ADO/DC

17/10/2014

Del SW ✓ 8/8/23

cfosys

9/8/2023

Director

KTD / pm