



C-19

75
आजादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI - 110001

No: F.6/DFS/MS/School/WZ/2023/549

Dated: 14/08/2023

FIRE SAFETY CERTIFICATE

Certified that the M.C. Primary School Located at Wazirpur Ind. Area, A Block, New Delhi -110052, comprised Ground + 01 Upper floor, was issued FSC vide letter No. F6/DFS/MS/School/WZ/2021/711 dated 06/09/2021, the premises was re-inspected by the officer concerned by this department on 01/08/2023 in the presence of Smt. Raj Bala Sharma (Principal) and observed that fire prevention and fire safety arrangements provide in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by DOE Circular no. 3298-3398 dated 01/03/2011 and that the building/premises is fit for occupancy class "Educational Building" (Group-B), as above with effect from .14/08/2023...for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to the compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 Condition printed below.

Issued on .14/08/2023.. at New Delhi.

(Atul Garg)
Director


Copy to: -

1. M.C. Primary School Located at Wazirpur Ind. Area, A Block, New Delhi -110052.
2. Director of Education, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : M.C. Primary School Located at Wazirpur Ind. Area, A-Block, New Delhi - 110052.
2. Type of Occupancy : Educational (Ground + 01 upper floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2021/711 dated 06/09/2021
5. Fire Safety directives letter No : DOE 3298-3398 dated 01/03/2011
6. Date of inspection : 01/08/2023
7. Name of the Inspecting Officers : Sarabjeet Singh ADO(MN)
8. Name and designation of officers from the building side : Smt. Raj Bala Sharma (Principal) 
9. Year of Construction : 1982 (As Per Prev. Insp. report dated: - 25/08/2021)
10. Applicant's letter No. : Email dated: - 19/07/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mtr	Provided	MR
	• Gate width	Accessible	350 cm Provided	MR (old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mts	2 x 140 cm	MR (old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	1.5 m	206 cm Provided	MR
	g. Door Size	1 mts	110 cm provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	04 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA



7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA

N/10		NA	NA	NA
17	Standby power supply	NA	NA	NA
Refuge Area.				
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection system provided in the building was test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety measure as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/WZ/2021/711 dated 06/09/2021 renewal under rule DOE Circular No. 3298-3398 dated 01/03/2011 is recommended.

188/ADO/MN
04/8/23

~~DOA~~
~~Exp. (Sh. M. K. C.)~~

~~8/8~~
~~04/08/2023~~
Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)

~~8/8~~
M.K. CHATTOPADHYAY
DCFO (MKE)

~~9/8/2023~~
Director

~~ADO MN~~

Sir, F.T is put-up for your kind personal & signature please.

~~Director~~
~~11/8/23~~

~~8/8~~
~~11/8/2023~~

n

DCFO/.....10/5.....
Dated.....8/8/2023.....