



C-126

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2023/SZ/ PKG-401

Dated: 17/08/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Multi Level, Car Parking at Terminal-3, IGI Airport, New Delhi-110037, comprised of ground plus six upper floors (Sixth floor for office purpose some portion) owned / occupied by Delhi International Airport Limited was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2020/SZ/407 dated 07/10/2020. The premises was re-inspected by the officer concerned of this department on 09/08/2023 in the presence of Sh. Anil Sharma (Fire officer) and found that the said parking building have deemed complied with the fire prevention and Fire Safety requirement in accordance with rule 33 of the Delhi Fire Service rules, 2010 and that the premises is fit for occupancy Class-H "Storage" (Car Parking) with effect from 17/08/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on 17/08/2023 at New Delhi by.

(ATUL GARG)
DIRECTOR
Delhi Fire Service

Copy to:-

1. Operational Head, Multi Level, Car Parking at Terminal-3, IGI Airport, New Delhi-110037.
2. Airport Rescue and Fire fighting, Delhi International Airport (P) Ltd. New Delhi-37

Conditions for the validity of Fire Safety Certificate

1. This FSC is only applicable for old existing MLCP Building (except addition alteration).
2. All the means of escape / entry / exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
4. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
5. All the staff members must know the correct method of operation of fire fighting system.
6. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
7. This certificate cannot be treated in any case for regularizations of unauthorized construction.
8. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
9. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **M/s Multi Level, Car Parking at Terminal-3, IGI Airport, New Delhi-110037**
2. Type of Occupancy: **Class-H "Storage"**
3. Building Comprised of: **Ground + 06 upper floors (Office at 6th floor).**
4. Type of Case: **Renewal**
5. Details of previous NOC: **F6/DFS/MS/2020/SZ/407 dated 07/10/2020**
6. Fire Safety directives Letter No.: **F6/DFS/MS/BP/2009/1247 dated 08/05/2009**
7. Date of inspection: **09/08/2023**
8. Name of the Inspecting Officer: **A.D.O. (S.J.) Santosh Kumar**
9. Name and designation of Officer from the building side: **Sh. Anil Sharma (Fire Operator)**
10. Year of Construction: **2010**
11. Applicant's letter no.: **Email ID- Nil dated 04/07/2023**

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements/ Existing Fire Protection system	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	9 m	MR
	• Gate width	6 m	6 m	MR
	• Width of internal road	6 m	6 m	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	5nos.+4 ramp	5nos.+4 ramp	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 m (each) + 4.5(each)	1.50 m (each) +4.5(each)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	5 Nos.	5 nos.	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	70 nos.	90 nos.	MR
	• Types	ABC & co2,W.co2	ABC & co2 , W.co2	MR
	• ISI marking	ISI marked	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	05 nos	05 nos	MR
	• Length of hose reel hose	30 mtrs	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke & Heat	Smoke & Heat	MR
	• Location of Main Panel	Ground Floor	Ground Floor	MR
	• Location of Repeater Panel	FCR	Fire control Room	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	On Each floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	150mm	150mm	MR
	• Number of hydrants per floor	5 nos.	5 nos.	MR
	• Hose Box	5 nos.	5 nos.	MR
12.	Yard Hydrants			
	• Total number of hydrants	11 nos	11 nos	MR
	• Hose Box	11 nos	11 nos	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	2280 LPM (Two)	Provided	MR
	➤ Head of main pump	80 m	Provided	MR
	➤ Number of main pumps	02 Nos	02 Nos	MR
	➤ Jockey pump out put	180 LPM (Two)	180 LPM (Two)	MR
	➤ Jockey pump head	80 m	80 m	MR
	➤ Standby Pump out put	2280 LPM	2280 LPM	MR
	➤ Standby Pump Head	80 m	80 m	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	1,00,000 ltr	1,00,000 ltr	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltr	Provided	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required for transformers, LT & HT panels	Provided (Co2 local application)	MR

Note:- Applicant submitted building plan were scrutinized for modifying of 135 sqm area of parking at 5th floor and addition of 218sqm area in existing office area 268sqm area at 6th floor in exciting MLCP..The department has issued a directive vide letter No.F.6/DFS/MS/BP/2023/642 dated 29/3/2023 which are not constructed by the authority (Undertaking attached).

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2020/SZ/407 dated 07/10/2020 renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

Santosh Kumar
11/08/23
Signature of the Inspecting Officer
Name : Santosh Kumar
Designation : A.D.O. (S.J.)

D.O. Santosh

Mersl
14/8

CP
14/8/2023
Director
14/8/23

Anil
17/8/23
P.T.O