



C 45

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/557

Dated: 17/08/2023

FIRE SAFETY CERTIFICATE

Certified that the building of Saheed Captain Sumit Rai, Govt. Sarvodaya Kanya Vidhyalaya No. 1, Located at Palam Enclave, New Delhi-110045. (S. ID.1821018) having 04 blocks comprised of Ground + One Upper Floor only was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2020/SZ/460, dated 03/11/2020. The premise was re inspected by the officer concerned of this department on 11/08/2023 in the presence of Mrs. Vijay (Principal). All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with DOE 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" with effect from 17/08/23 for a period of three years, subject to compliance of the condition given below.

Issued on 17/08/2023... at New Delhi by.


(Atul Garg)
Director

Delhi Fire Service

ok

Copy to: -

1. The Principal, Saheed Captain Sumit Rai Govt. Sarvodaya Kanya Vidhyalaya No. 1, Palam Enclave, New Delhi-110045.
2. Directorate of Education Old Secretariat Delhi - 110054

Following fire safety directives must be adhered to:-

1. Pota cabins are seen in the school premises shall not be used for school activities. The FSC shall be null & void if pota cabin is used for school activities
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used strictly as per building bye laws.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.

N/23

INSPECTION REPORT

1. Name & address of the building: Saheed Captain Sumit Rai Govt. Sarvodaya Kanya Vidhyalaya No. 1, Located at Palam Enclave, New Delhi-110045. (S. ID.1821018)
2. Type of Occupancy : Educational (04 blocks= G +One Upper Floor Only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2020/SZ/460, dated 03/11/2020
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 11/08/2023
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Mrs. Vijay (Principal)
9. Year of Construction : 2005,2010 & 2016
10. Applicant's letter No. : Email dated 01/08/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/9, N/10 & N/11	Provided at site	Remarks MR/NMR
1.	Access of building	06 mtr	Provided	MR
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible	Provided	MR
		NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	07 Nos.	8 Nos.	MR
	<ul style="list-style-type: none"> • Upper floors • Basements 	NA	NA	NA
	b. Width of staircases	1.5 m	BL B=2 m & 1.5 m, 106cm BL C= 1.55m & 1.56m BL D=1.55m & 1.56m BL F=1.5 m	MR Old case
	<ul style="list-style-type: none"> • Upper floors • Basements 	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1.5 m	Provided	MR Old Case
	e. Width Of Corridor	1 mtr	Provided	MR
	f. Door Size			



N/24

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	18 Required	18 Nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

[Handwritten signature]

