



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/ 566

Dated: 21/08/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Girls Sr. Sec. School (School ID-1207230) located at Mukund Pur Village, Janta Vihar, Delhi-110042 comprised of Ground floor & 03 upper floors only owned/ occupied by the Govt. Girls Sr. Sec. School was issued FSC by this department vide letter F6/DFS/MS/School/2020/350 Dated 15.09.2020. The premise was inspected by the officer concerned of this department on 08.08.2023 in the presence of Mr. R.K. Singh (Estate Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rules 33 of the Delhi Fire Service Rules, 2010 and building premises is fit for occupancy class "Group B" Educational with effect from 21.08.2023... for a period of Valid up to 31.03.2026 in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 21/08/2023 at New Delhi

(Signature)  
Director

Ph:-011-23414000

(Signature)

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Govt. Girls Sr. Sec. School (School ID-1207230) located at Mukund Pur Village, Janta Vihar, Delhi-110042.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doiit/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization ( Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration ( Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

**INSPECTION REPORT**

1. Name & address of the building : Govt. Girls Sr. Sec. School located at Mukund Pur Village, Janta Vihar, Delhi-110042. (School ID-1207230)
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : New Block, Ground & 03 upper floors only
5. Details of previous NOC : F.6/DFS/MS/School/2020/350 Dated:- 15.09.2020
6. Fire Safety directives letter No : Nil
7. Date of inspection : 08.08.2023
8. Name of the Inspecting Officers : ADO (RN), Chittanlal Meena
9. Name and designation of officers from the building side : Sh. R.K. Singh (Estate Manager)
10. Year of Construction : 2017
11. Applicant's letter No. : Online E-mail I.D dated: 01.08.2023

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	06m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.80m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	02	MR
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	01m	1.10m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilated	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	30nos	54nos	MR
	• Types	ABC/Co2	Provided	MR
	• ISI marking	ISI Marked	Provided	MR



6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	02nos	Provided	MR
	• Length of hose reel hose	30 m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450lpm	450lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	60,000 LTR	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA

N/29

	• Overhead Tank capacity	10,000ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked and found in working condition at the time of inspection. The observations/ shortcomings issued and communicated vide this department letter of even no.F6/DFS/MS/2023/School/287 dated.31.05.2023 have been compiled by the management.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules. It is recommended to renew Fire Safety vide this department letter of even no. F6/DFS/MS/School/2020/350 dated.15.09.2020 Certificate under rule 37(3) of Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer  
 Name :- C.L. Meena  
 Designation:- Asst. Div. Officer (RN)

M.K. Chattopadhyay  
 Dy. Chief Fire Officer

15  
 09/08/23

9/8

10/8/2023

Director  
 11/8/23

11/8/23

Cont. P.T.O. - - -