



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2023/561

Dated: 21/08/2023

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Sr. Sec. School, (New Block) Located at Shalimar Village, New Delhi – 110088, comprised of Ground + 03 Upper Floors Owned/Occupied by Govt. Girls Sr. Sec. School, (New Block), The premises was inspected by the officer concerned by this department on 03/08/2023 in the presence of Sh. Hukum Singh (Estate Manager) and observed that fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Act 2007 & Delhi Fire Service Rules 2010, and that the premises is fit for occupancy class “Educational” Group-B, with effect from ...21/08/2023... for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to the compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 Condition mentioned below.

Issued on 21/08/2023. at New Delhi.

(Atul Garg)
Director

Copy to:

1. The Principal, Govt. Girls Sr. Sec. School, Located at Shalimar Village, New Delhi - 110088.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.
3. Assistant Engineer (E), PWD, EDu. Ele. Edn. 1, Sub -Division-4, Edu. Elect. Edn. 1 Div. (N) Zakhira, Rama Road, New Delhi-110015.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : Govt. Girls Sr. Sec. School, (New Block), Shalimar Village, New Delhi – 110088.
2. Type of Occupancy : Educational
3. Type of Case : New Case
4. Details of previous NOC : N/A
5. Fire Safety directives letter No : N/A
6. Date of inspection : 03/08/2023
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (MN)
8. Name and designation of officers from the building side : Sh. Hukum Singh (Estate manager)
9. Year of Construction : 2021-22
10. Applicant's letter No. : Email dated 19/07/2023

* The said school building is comprised of ground plus three upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per NBC-IV/UBBL	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2	Provided	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases	2 x 1.5 mts	2 x 1.80 mts	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	02	02	MR
	e. No. of continuous staircases to terrace	1.5m	Provided	MR
	f. Width of Corridor	1 m	Provided	MR
	g. Door Size			
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	N/A	NA
	• Upper floors	Required	Natural ventilation provided	MR
5	Fire Extinguishers			
	• Total numbers	14 nos.	Provided	MR
	• Types	ABC & CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	2	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	Provided	NA
	• Number of hydrants per floor	NA	Provided	NA
	• Hose Box	NA	Provided	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	2 X 450 LPM	Provided	MR
	➤ Head of the pump	30 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

Provision of Lifts.			
•	Pressurization of Lift Shaft	NA	NA
	Pressurization of Lift lobby	NA	NA
	Communication In lift Car	NA	NA
	Fireman's Grounding Switch	NA	NA
	Lift Signage	NA	NA
		NA	NA
17	Standby power supply		
18	Refuge Area.		
	➤ Total Area	NA	NA
	➤ Location	NA	NA
19	Fire Control Room		
•	Detector System Panel	NA	NA
	Flow Switch Panel	NA	NA
	PA System Panel	NA	NA
	Batter backup	NA	NA
	Building Floor Plans	NA	NA
		NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:		

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued by this department vide letter no F6/DFS/MS/School/WZ/2022/540 dated 06/09/2022, F6/DFS/MS/School/WZ/2023/28 dated 16/01/2023 & F6/DFS/MS/School/WZ/2023/262 dated 22/05/2023 have been complied.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

ADO/MN
4/8/23

DO (1/2)
Ag. (sh. m. k. c.)

df

cfo

9/8/2023
M.K. CHATTOPADHYAY

Director

9/8/23

DFM/KI

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

14/8

ADO (MN)

DCFO/10/6
Dated 6/8/23