



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/ 569

Dated: 22/08/2023

FIRE SAFETY CERTIFICATE

Certified that the **Guru Tegh Bahadur Public School** located at **Model Town, Northex, Delhi-110009** comprised of **Basement, Ground first floor only** owned/ occupied by **Shri Guru Tegh Bahadur Public School Society (Regd.)** The premise was re-inspected by the officer concerned of this department on **14.08.2023** in the presence of **Mr. Tarandeep Singh (Admin)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from **..22/08/2023** for a period of **Valid up to 31.03.2026** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on **..22/08/2023** at New Delhi by


(Atul Garg)
Director
Ph:-011-23414000

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Guru Tegh Bahadur Public School, Model Town, Northex, Delhi-09.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Guru Tegh Bahadur Public School, Model Town, Northex, Delhi-09.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : Basement, Ground & first floor only
5. Details of previous NOC : F6/DFS/MS/2017/School/WZ/527 dated : 11.04.2017
6. Fire Safety directives letter No : F.6/DFS/MS/BP/2015/44 dated 17/02/2015/
7. Date of inspection : 14.08.2023
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Sh. Tarandeep Singh (Admin)
10. Year of Construction : 2015
11. Applicant's letter No. : Online E-mail ID dated 07.08.2023

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1	Access to building	Accessible	Accessible	MR
	• Road width	4.50m	Provided	MR
	• Gate width	6m	6m	MR
	• Width of internal road			
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	05	05	MR
	• Upper Floors	05	05	MR
	• Basements			
	b. Width of staircases	1.50m	1.60 m x02 & 1.50 x 03 each	MR
	• Upper Floors	1.50m	1.50m x 05	MR
	• Basements			
	c. Protection of exits	Required	Provided	MR
	• Fire check door	NA	NA	NA
	• Pressurization			
d. No. of continuous staircases to terrace	03	03	MR	
e. Width of Corridor	1.50m	03m	MR	
f. Door Size	1.2 m	1.2 m	MR	
3	Compartmentation.	NA	NA	NA
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Required	Provided	MR
	• Fire Dampers	Required	Provided	MR
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	15nos	15nos	MR
	• Types	ABC/CO2	ABC—15	MR
	• ISI marking	ISI Marked	Yes	MR


6	First-Aid Hose Reels.			
	• Total numbers on each floor	05nos	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	150mm	Provided	MR
	• Number of hydrants per floor	05	Provided	MR
	• Hose Box	05	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	2850 lpm	2850lpm	MR
	➤ Head of Main pump	70m	70m	MR
	➤ Number of main pumps	01	01	MR
	➤ Jockey Pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	40m	Provided	MR
	➤ Standby Pump out put	2850 lpm	2850lpm	MR
	➤ Standby Pump Head	70m	70m	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump	900lpm	900lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
➤ Auto Starting of pump	Required	Provided	MR	
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	1, 00,000ltr.	1, 00,000ltr.	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	25000 ltrs	Provided	MR
				MR
	Exit Signage.	Required	Provided	MR
	Provision of Lifts.			

	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part 4, the FSC issued vide letter of even no. F6/D/S/MS/2017/School/WZ/527 dated 11.04.2017 renewal under rule 35(6) of the Delhi Fire Service Rules, 2010 is recommended.

M.K. Chattopadhyay
Dy. Chief Fire Officer



M.K. CHATTOPADHYAY

[Signature]
12/18

[Signature]

Director
18/01/2022
[Signature]
10/01/22

[Signature]
Signature of the Inspecting Officer
Name:- C.L. Meena
Designation:- Asst. Div. Officer (RN)

JCFO/.....50.....
Dated.....17/08/22.....

As approved, F.T. letter is setup for your signature pl.

[Signature]
B.T.O.
21/08/22