

C102

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2023/WZ/college/23

Dated: 21/08/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Health & Education Society, 3-PSP, Institutional Area, Madhuban Chowk, Rohini, Delhi-110085, comprised of Basement + Ground + 04 upper floors has already been issued FSC by this department vide letter No. F.6/DFS/MS/2018/WZ/2331 dated 15.10.2018. The premises was re-inspected by the officer concerned of this department on 03.08.2023 in the presence of Mr. Ajay Kumar (Director) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group B Educational** with effect from 21/08/2023 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/08/2023.. at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to: -

1. Dr. Ajay Kumar (Director) M/s Health & Education Society, 3-PSP, Institutional Area, Madhuban Chowk, Rohini, Delhi-110085.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : Health & Education Society, 3-PSP, Institutional Area, Madhuban Chowk, Rohini, Delhi-110085.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Basement + Ground + 04 upper floors)
4. Details of Previous NOC : F.6/DFS/MS/2018/WZ/2331 dated 15.10.2018.
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2001/147 dated 22.01.2001.
6. Date of inspection : 03.08.2023
7. Name of Inspecting Officer : A. K. Sharma, ADO (Rohini) & D.B Mukherjee, DO (NW)
8. Name and designation of officers
From the building side : Mr. Ajay Kumar (Director)
9. Year of Construction : 2006
10. Applicant's letter No. : Online e-mail dated 23.005.2023.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Approachable	Provided	MR
	• Gate width	4.5m	On Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02nos.	02nos.	MR
	• Basements	03nos.	03nos.	MR
	b. Width of staircases			
	• Upper Floor	1.25m	1.2 & 1.15m	MR(Old Case)
	• Basements	1.25m	1.18, 1.25 & 1.15m	MR(Old Case)
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Required	02nos.Provided	MR
	e. Width of Corridor	1.25m	1.25m	MR
	f. Door Size	1.0m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	Exhaust fan	MR
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	300@	15nos.	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	Provided	MR
	• Location of Main Panel	NA	Ground floor	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	Battery	MR

Original

N/21

	• Hooters' Location	NA	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	1620lpm	1620lpm	MR
	➤ Head of Main pump	55M	55M	MR
	➤ Number of main pumps	01	01	MR
	➤ Jockey Pump out put	180lpm	180lpm	MR
	➤ Jockey pump head	55M	55M	MR
	➤ Standby Pump out put	1620lpm	1620lpm	MR
	➤ Standby Pump Head	55M	55M	MR
	➤ Auto Starting/Manual Stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	450lpm	450lpm	MR
	➤ Head of the pump	35M	35M	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	50,000ltr	Provided	MR
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA

N/22


Special Fire Protection System for Protection of special Risks, if any:	Required	Co2 fire extinguishers provided	MR
--	----------	---------------------------------------	----

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.


Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 77 dated 22.12.2022, the FSC issued vide letter no. F.6/DFS/MS/2018/WZ/2331 dated 15.10.2018, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.


04/08/2023

Signature of the Inspecting Office
Name: - D.B Mukherjee
Designation:- DO/NW


4/8/22


Signature of the Inspecting Officer
Name: - Ajay Kumar Sharma
Designation:- ADO/Rohini

cto
11/8/2023
Director

14/8/2023



FI letter is put up
for kind perusal and
signature please.


17/8/22

Director

10/8/22
mu