

C-35

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/2023/School/NDZ/ 597

Dated:-30.08.2023

FIRE SAFETY CERTIFICATE

Certified that the **Chowgule Public School** located at **D-4, Faiz Road, Karol Bagh, New Delhi** comprises of **Basement + Ground + 03 upper floor** was earlier granted FSC by this department vide letter No. F6/DFS/MS/2020/School/NDZ/253 dated 28/07/2020. Now, the premises was re-inspected by the officer concerned of this department on 22-08-2023 in the presence of **Ms. Pooja Salpekar (Principal)** and found that the said school building have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class Group B "Educational Building" with effect from30.08.2023 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on 30.08.2023 at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT, Delhi
2. The Principal, Chowgule Public School, D-4, Faiz Road, Karol Bagh, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

119
INSPECTION REPORT

1. Name & address of the building:- Chowgule Public School located at D-4, Faiz Road, Karol Bagh, New Delhi
2. Type of occupancy:- Educational Group-B
B + Gr. + 03 Upper floor
3. Type of case:- Renewal
4. Details of previous NOC:- F6/DFS/MS/2020/School/NDZ/253 dated 28/07/2020
5. Fire safety directives No.- N/A
6. Date of inspection:- 22/08/23
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
From the building side:- Ms. Pooja Salpekar (Principal)
9. Year of construction:- 1986
10. Applicant's letter No:- letter no. Nil dated 25/07/2023

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Exiting	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	09 mtr.	MR
	2) Gate width	4.5 mtr.	4.90 mtr.	MR
	3) Width of internal road	03 mtr.	3.10 mtr.	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	03	MR
	2. Basements	02	02	MR
	B. Width of staircase			
	1. Upper floors	1.2 Mtr	1.20 mtr. each	MR old
	2. Basements	1.2 mtr.	1.20 mtr. each	MR old
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	03	MR
	E. Width of corridor	1.5 mtr.	1.5 mtr.	MR
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements (190 SQM)	30 ACPH	Provided	MR
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	24 Nos.	24 Nos	MR
	2) Types	ABC & CO2	ABC, CO2 & W CO2	MR
	3) ISI marking	N/A	N/A	N/A




N/29

6.	First-Aid Hose Reel			
	1) Total number of each floor	02	02	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	02	02	MR
	3) Hose box	02	02	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	900 LPM	900 & 235 LPM	MR
	b) Head of pump	30 mtr	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	15,000 ltrs.	15,000 ltrs.	MR

✓

✓

✓

15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			ABC Type cap. F.Exit Es/Panel

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection..

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no No F6/DFS/MS/2020/School/NDZ/253 dated 28/07/2020, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

[Handwritten Signature]

Name: - Ravinder Singh
Designation: - ADO (CC)

[Handwritten Signature]
24/8

[Handwritten Signature]
25/8/2023

[Handwritten Signature]
25/8/2023

e.f.o.
[Handwritten Signature]
25/8/2023

Director
[Handwritten Signature]
20/10/23

[Handwritten Signature]