



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2023/NDZI 596

Dated: 30/08/2023

FIRE SAFETY CERTIFICATE

Certified that the Govt. Co-ed. Middle School located at East Rohtas Nagar, Shahdara, Delhi-110032 comprised of ground floor only owned/occupied by Govt. Co-ed. Middle School was issued FSC vide letter No. F.6/DFS/MS/S/2020/05 dated 08/01/2020. The premises was re-inspected by the officer concerned of this department on dated 31/07/2023 in the presence of Mr. Om Singh, Principal and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from 30/08/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 30/08/2023..... at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

To:-

The Principal,
Govt. Co-ed. Middle School located at East Rohtas Nagar, Shahdara, Delhi-110032

Copy to:-

The Dy. Director of Education,
B-Block, Yamuna Vihar New Delhi-110053

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

INSPECTION REPORT

1. Name & address of the building : Govt. Co-ed. Middle School, East Rohtas Nagar, Shahdara, Delhi-110032
2. Building is comprised of : Ground floor ✓
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/S/2020/05 dated 08/01/2020 ✓
6. Fire Safety direction letter No. : F16/Estate/CC/Fire Safety/2011/3298 to 3398 dt- 01/03/11
7. Date of Inspection : 31/07/2023
8. Name of the Inspecting officers : ADO Deepak Kumar
9. Name and designation of Officer from the building side : Mr. Om Singh, Principal
10. Year of Construction : 1970
11. Applicant's letter No : Nil dated 31/07/2023

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06m	04m	MR(old case accepted)
		04m	04m	MR
		N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	N/A	N/A	N/A
		N/A	N/A	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	N/A	N/A	N/A
		N/A	N/A	N/A
	c. Protection of Exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	1.50m	1.5m	MR
	f. Door Size	01m	01m	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	N/A	N/A	N/A
		N/A	N/A	N/A
05.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	04 nos.	09 nos.	MR
		ABC/CO ₂	ABC/CO ₂	MR
		ISI marked	ISI marked	MR

E.A

W/

06	First-Aid-Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A		N/A
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A

✓ ✗ 50/ ✓

16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft • Pressurization of lift lobby • Communication in lift car • Firemen's grounding switch • Lift signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building floor plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule. The FSC issued vide letter no. F.6/DFS/MS/S/2020/05 dated 08/01/2020 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Deepak
01/08/2023
Signature of the Inspecting Officer
Name :- Deepak Kumar
Designation :- A.D.O (Shd)

~~DO(ED)~~ DFA please.

By: *CFO/NDU*
C.F.O.
12/8/2022
2/10/22
01/08/2023
02/08/23
01/08/2023
A.D.O (Shd)