

C 39

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/School/587

Dated: 24/08/2023

FIRE SAFETY CERTIFICATE

Certified that the building of Govt. Co-ed Sr. Sec. School Located at Prem Nagar, New Delhi-110008 (School I.D-1516030), having 03 blocks comprised of Ground + One Upper Floor was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/SZ/2019/146, dated 18/01/19. The premise was re inspected by the officer concerned of this department on 17/08/2023 in the presence of Ms. Monika (Principal). All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with DOE 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" with effect from 24/08/2023 for a period of three years, subject to compliance of the condition given below.

Issued on 24/08/2023. at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
OK

Copy to: -

1. The Principal, Govt. Co-ed Sr. Sec. School at Prem Nagar, New Delhi-110008. (School I.D-1516030).
2. Directorate of Education Old Secretariat Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

11/28

INSPECTION REPORT

1. Name & address of the building: Govt. Co-ed Sr. Sec. School Located at Prem Nagar, New Delhi-110008 (School I.D-1516030).
2. Type of Occupancy : Educational (03 Blocks=BL=A,B,C= Ground +One Upper Floor) Inter connected each other
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/SZ/2019/146, dated 18/01/19.
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 17/08/2023
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Ms. . Monika (Principal)
9. Year of Construction : 1996, 2012, 2014 & 2015
10. Applicant's letter No. : GGSSS/PN/892 dated 08/08/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/19, N/20 & N/21	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR (Being old case)
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3 Nos.	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m or less & 0.75m	Provided	MR (Being old case)
	• Basements	NA	NA	NA
	c. Protection of exits ,			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old case	1 mtr	MR(Being old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

14. Captive water Storage for fire fighting:			
• Underground tank capacity	NA	NA	NA
➤ Draw off connection	NA	NA	NA
➤ Fire service inlet	NA	NA	NA
➤ Access to tank	NA	NA	NA
• Overhead Tank capacity	NA	NA	NA
15. Exit Signage	Required	Provided	MR
16. Provision of Lifts			
➤ Pressurization of Lift Shaft	NA	NA	NA
➤ Pressurization of lift lobby	NA	NA	NA
➤ Communication in lift Car	NA	NA	NA
➤ Fireman's Grounding Switch	NA	NA	NA
➤ Lift Signage	NA	NA	NA
17. Standby power supply	NA	NA	NA
18. Refuge Area			
➤ Total area			
➤ Location	NA	NA	NA
19. Fire control room			
➤ Detector system panel	NA	NA	NA
➤ Flow Switch Panel	NA	NA	NA
➤ PA System Panel	NA	NA	NA
➤ Battery backup	NA	NA	NA
➤ Building Floor Plans	NA	NA	NA
20. Special Fire Protection Systems for Protection of special Risks, if any;	Required	01 ABC fire extinguisher provided near electric meter	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/SZ/2019/146, dated 18/01/19 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note: - Two blocks comprised of G+2 UF are also located in the same premises. The FSC is recommended for only three blocks comprised of G+1 UF only.

Signature of the Inspecting Officer
 Name *Uday Kir Singh*
 Designation *ASO/DCR*

DO/SW
21/8/23

CFO/S2
21/8/2023

Delectat

Amey/owner