

C 44



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2023/ 593

Dated: 30/08/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Sarvodaya Kanya Vidyalaya. O-Block Mangolpuri, Delhi-110083.(School ID-1412031), comprised of Five blocks- 04 Blocks Ground + 01 upper floors & one block- ground + 03 upper floors has already been issued FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2020/535 dated 04.12.2020. The premises was re-inspected by the officer concerned of this department on 10.08.2023 in the presence of Mrs. Renu Yadav (Principal) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy **Group B Educational** with effect from 30/08/2023 for a period of **three years**, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

. Issued on 30/08/2023 at New Delhi by

  
(Atul Garg)  
DIRECTOR

Ph; 011-23414000

SL  
C44

**Copy to:**

1. The Principal, Govt. Sarvodaya Kanya Vidyalaya. O-Block, Mangolpuri, Delhi-110083. (School ID-1412031),
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054

**Conditions for validity of Fire Safety Certificate;**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on

<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Fire+Safety+Acts+and+Rules/>  
<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Forms>

N/24

### INSPECTION REPORT

1. Name & address of the building : Govt. Sarvodaya Kanya Vidyalaya. O-Block, Mangolpuri, Delhi-110083. (School ID-1412031)
2. Type of Occupancy : Educational
3. Type of Case : Renewal (05 blks-04 blk gr. + 1 upper floor & 01-blk-Gr.+ 3)
4. Details of Previous NOC : F.6/DFS/MS/School/WZ/2020/535 dated 04.12.2020
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 10.08.2023
7. Name of Inspecting Officer : A.K.Sharma ADO (Rohini)
8. Name and designation of officers  
From the building side : Mrs. Renu Yadav (Principal)
9. Year of Construction : 2017
10. Applicant's letter No. : OD No3797 dated 14.07.2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<p>06m 4.5m N/A</p>	<p>06m 4.5m N/A</p>	<p>MR MR N/A</p>
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	d. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	<p>12 N/A</p>	<p>12 N/A</p>	<p>MR N/A</p>
	e. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	<p>1.50m N/A</p>	<p>Blk-I-1.70, 1.50 &amp;, 1.45m II-1.45 x 02 &amp; 1.70m III-1.50m IV-1.45 x 02 &amp; 1.70m V-(G+3)-2 x 1.70m N/A</p>	<p>MR N/A</p>
	f. Protection of exits			
	Fire check door			
	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	<p>N/A N/A</p>	<p>N/A N/A</p>	<p>N/A N/A</p>
	d. No. of continuous staircases to terrace	01	02	MR
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	1m	1m	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<p>N/A N/A N/A N/A N/A</p>	<p>N/A N/A N/A N/A N/A</p>	<p>N/A N/A N/A N/A N/A</p>
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	<p>30 a/c per hour 12 a/c per hour</p>	<p>N/A Natural ventilated</p>	<p>N/A MR</p>
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	<p>26nos ABC/Co2 ISI Marked</p>	<p>28nos ABC-18, Co2-10 Provided</p>	<p>MR MR MR</p>

g

Raj

N/25

Pres.  
P.  
17.  
18.

6.	<b>First-Aid Hose Reels</b> <ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	02	Provided	MR
		30m	30m	MR
		5mm	5mm	MR
7.	<b>Automatic fire detection and alarming system</b> <ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	N/A	N/A
			N/A	N/A
			N/A	N/A
			N/A	N/A
			N/A	N/A
			N/A	N/A
8.	<b>MOEFA</b>	N/A	N/A	N/A
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b> <ul style="list-style-type: none"> <li>Basement</li> <li>Ground &amp; Upper Floors</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	<b>Internal Hydrants</b> <ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	01	Provided	MR
		01	Provided	MR
		01	01	MR
12.	<b>Yard Hydrants</b> <ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
13.	<b>Pumping Arrangements</b> <ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	450lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b> <ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10,000ltr	10,000ltr	MR
		Required	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			

Chy X

N/28

MR MR MR	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/School/WZ/2020/535 dated 04.12.2020 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

*Ajay*  
21/12/23  
Signature of the Inspecting Officer  
Name Ajay Kumar Sharma  
Designation ADO(Rohini)

Dy. CFO (WZ)

*M.K.*  
22/12/23  
M.K. CHATTOPADHYAY

01.84  
22/12/23

*CFO*  
*23/12/2023*  
Director

*ADO (Rohini)*

*ACFO/MK*  
*23/12/23*

FT letter to put up for kind  
perusal and signature please

*Director*  
*29/12/23*

*Ajay*  
23/12/23