



7.9.12  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/School/2023/NDZ/600

Dated: 30/08/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **Himalaya Public School** located at **Pusta Road, West Karawal Nagar, Delhi 110094**, building comprised of **Ground plus One upper Floors**, owned / occupied by Himalaya Public School, was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2019/NDZ/1680 Dt. 27/08/2019. The School building was re-inspected by the officer concerned of this department on 24/08/2023 in presence of Sh. Dinesh Chand Sharma and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the Fire Prevention and Fire Safety Requirements in accordance with Circular No. 262-362 Dated 17/01/2005 issued by Director of Education and the building/premises is fit for occupancy class "**Educational**" (**Group-B**) with effect from 30/08/2023 for a period of **three years**, subject to conditions printed below.

**Issued on 30/08/2023 at New Delhi by.**

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Principal, Himalaya Public School, Pusta Road, West Karawal Nagar, Delhi 110094.
2. Director of Education, B-Block, Yamuna Vihar, North East, Delhi-110053.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

**INSPECTION REPORT**

1. Name & address of the building: Himalaya Public School,  
Pusta Road, West Karawal Nagar, Delhi 110094.
- Building is comprised of : G+1 Upper Floors
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2019/NDZ/1680 Dt. 27/08/2019
5. Fire Safety directives Letter No.: Circular No. 262-362 Dt. 17/01/2005 ✓
6. Date of inspection : 24/08/2023
7. Name of the Inspecting Officer : A.K. Jaiswal, D.O. (E.D.)
8. Name and designation of Officer  
from the building side : Sh. Dinesh Chand Sharma
9. Year of Construction : 2006
10. Applicant's Letter No. : H.P.S./DFS/2023 Dated 07/08/2023

S.No.	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E. Cir Req. 17/01/2005	Provided at Site	Remarks
1	Access to building			
	• Road width	6 m	6 m	M/R
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01 nos.	02 nos.	MR
	• Basement	N/A	N/A	N/A ✓
	b. Width of Staircases			
	• Upper Floor	1.50 m	1.10 m each	MR (old accepted)
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 nos.	01 nos.	MR
	e. Width of Corridor	1.50 m	1.50 m	MR ✓
	f. Door size	1.00 m	1.00 m	MR ✓
3	Compartmentation			
	• Fire check Door	N/A	N/A	N/A
	• Sealing of electrical Shafts	N/A	N/A	N/A
	• Fire rating of Shaft Door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System			
	• Basement	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
5	Fire Extinguishers			
	• Total Numbers	04 Nos.	06 Nos.	MR ✓
	• Types	ABC & Co2	ABC & Co2	MR
	• IS Marking	ISI Marked	ISI Marked	MR

*(Handwritten signature)*

*(Handwritten signature)*

N/A			
6	<b>First-aid-Hose Reels</b>		
	• Total numbers of each floor	01 nos.	01 nos. MR
	• Length of hose reel hose	30 m	30 m MR
	• Nozzle diameter	05 mm	05 mm MR
7	<b>Automatic fire detection and alarming system</b>		
	• Type of detectors	N/A	N/A N/A
	• Location of main panel	N/A	N/A N/A
	• Location of repeater panel	N/A	N/A N/A
	• Alternate source of power	N/A	N/A N/A
	• Hooter's location	N/A	N/A N/A
8	<b>MOEFA</b>	N/A	N/A N/A
9	<b>Public address System</b>	N/A	N/A N/A
10	<b>Automatic Sprinkler System</b>		
	• Basement	N/A	N/A N/A
	• Upper Floor	N/A	N/A N/A
	• Sprinkler above false Ceiling	N/A	N/A N/A
11	<b>Internal Hydrants</b>		
	• Size of rise/down-comer	N/A	N/A N/A
	• Number of Hydrants per Floor	N/A	N/A N/A
	• Hose Box	N/A	N/A N/A
12	<b>Yard Hydrants</b>		
	• Total number of Hydrants	N/A	N/A N/A
	• Hose Box	N/A	N/A N/A
13	<b>Pumping Arrangements</b>		
	• Ground Level		
	➤ Discharge of main Pump	N/A	N/A N/A
	➤ Head of Main Pump	N/A	N/A N/A
	➤ Number of main Pumps	N/A	N/A N/A
	➤ Jockey pump output	N/A	N/A N/A
	➤ Jockey pump head	N/A	N/A N/A
	➤ Standby pump output	N/A	N/A N/A
	➤ Standby pump head	N/A	N/A N/A
	➤ Auto starting/Manual stopping	N/A	N/A N/A
	➤ Pump house access	N/A	N/A N/A
	• Terrace Level		
	➤ Discharge of pump	220 LPM	Provided MR
	➤ head of the pump	40 m	Provided MR
	➤ Power supply	Required	Provided MR
	➤ Auto Starting of pump	Required	Provided MR
14	<b>Captive Water Storage for Fire Fighting</b>		
	• Underground tank capacity	N/A	N/A N/A
	➤ Draw-off connection	N/A	N/A N/A
	➤ Fire service inlet	N/A	N/A N/A
	➤ Access to tank	N/A	N/A N/A
	• overhead Tank capacity	2500 Ltrs.	2500 Ltrs. MR
15	<b>Exit Signage</b>	Required	Provided MR

31

16	Provision of Lifts			N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	
18	Refuge Area			N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required in Director of Education Circular No. 262-362 Dt. 17/01/2005, The Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2019/NDZ/1680 Dt. 27/08/2019 is recommended to be renewed.

*Ashok*  
25/8/2023

Signature of the Inspecting Officer  
Name: Ashok Kumar Jaiswal  
Designation: D.O. (East. Div.)

~~Dy. C.O. (NDZ)~~

~~28/08/23~~

~~C.F.O. 29/8/2023~~  
~~Director 29/10/2~~

~~D.O. (East)~~

F.T. Letter is put up for signature of  
Director 29/10/23  
30/08/2023