

C 33

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/584

Dated: 24/08/2023

FIRE SAFETY CERTIFICATE

Certified that the building Jindal public School, Located at Dashrathpuri Dwarka, Palam road, New Delhi - 110045 having two blocks A Block comprised of Ground + 02 Upper floors & B Block comprised of Ground + 01 Upper floor was issued FSC vide Letter No. F.6/DFS/MS/School/2020/SZ/216, dated 10/07/2020. The premises was re inspected by the officer concerned of this department on 09/08/2023 in the presence of Sh. Uttam Singh (Principal) and found that the said building have deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262-362 Dated 17/01/2005 and that the building is fit for occupancy class B "Educational building" with effect from 24/08/2023 for a period of three in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/08/2023 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
o/c
23/8/23

Copy to:

1. The Principal, Jindal public School, Located at Dashrathpuri Dwarka, Palam road, New Delhi - 110045.
2. Directorate of Education Old Secretariat Delhi - 110054.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Jindal public School, Located at Dashrathpuri Dwarka, Palam road, New Delhi – 110045.
2. Type of Occupancy : Educational (02 Blocks G+2 UFs & G+1 UFs)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2020/SZ/216, dated 10/07/2020
5. Fire Safety directives Letter No: DOE Circular. 262-362, dated 17/01/2005
6. Date of inspection : 09/08/2023
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Uttam Singh (Principal)
9. Year of Construction : 2001
10. Applicant's letter No. : Email Dated -14/07/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/10, N/11 & N/12	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5mtrs	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	A Blk=3Nos. & B Blk=2 Nos.		Provided MR
	• Basements	NA		NA NA
	b. Width of staircases			
	• Upper floors	1.5 mtr (In each Block)	Bl. A= 1.5 m (up to 1 st floor), 1.25 & 1.22 m Bl. B= 1.28m & 75 cm	MR (Being old case)
	• Basements	NA		NA
	c. Protection of exits			
	• Fire check door	NA		NA
	• Pressurization	NA		NA
	d. No of continuous staircase to terrace	Required		02 Nos. each block MR
	e. Width Of Corridor	NA		NA
	f. Door Size	01 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NA		NA
	• Sealing of electrical shafts	NA		NA
	• Fire Rating of shaft door	NA		NA
	• Water Curtain	NA		NA
	• Fire Dampers	NA		NA
4.	Smoke managements System			
	• Basements	NA		NA
	• Upper floors	12 a/c per hour	Natural ventilation	MR

20/8

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F.6/DFS/MS/School/2020/SZ/216, dated 10/07/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation APO/DIR

Dof/SW 11/8/23

CFD (S2) 16/8/2023

Director 16/8/23

AOC/DIR

Sir AT, letter is put up for sign file

DIRECTOR 29/8/23