

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No. F.6/DFS/MS/School/2023/SZ/590

Dated: 28/08/2023

FIRE SAFETY CERTIFICATE

Certified that the **Oxford Angel Public School** located Kh. No 260/3, Maidan Garhi Road, Chhattarpur, New Delhi-110074 comprised of Basement, Ground plus three upper floors (But FSC issued upto 2nd floor only) owned/occupied by Oxford Angel Public School was issued FSC by this department vide letter No. F.6/DFS/MS/School/2020/SZ/109 dated 12-03-2020. The premises was re-inspected by officer concerned of this department on 21/08/2023 in the presence of Mr. Narender Satya Garg and found that the premise have deemed complied with the fire prevention and fire safety requirements in accordance with fire safety requirements in accordance with circular no Directorate of Education Circular No 262-362 dated 17/01/2005 issued by Director of Education, Govt. of NCT of Delhi and that building is fit for occupancy class "**Educational, Group-B**" with effect from 28/08/2023 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 28/08 /2023 at New Delhi by


(VIRENDRA SINGH)
CHIEF FIRE OFFICER (HQ)
DELHI FIRE SERVICE

Copy to: -

1. The Director, Oxford Angel Public School located Kh. No 260/3, Maidan Garhi Road, Chhattarpur, New Delhi-110074
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of UBBL /NBC Part-IV.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

N/98

INSPECTION REPORT				
1	Name & Address of the Building	Oxford Angel Public School, located Kh. No 260/3, Maidan Garhi Road, Chhattarpur, New Delhi-110074.		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Basement, Ground + 03 upper floors (3 rd Floor not for use)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2020/SZ/109 dated 12-03-2020 for B +G + 2 Upper Floor		
6	Fire Safety Directives Letter No	DOE Circular No – 262-362 dated 17/01/2005		
7	Date of Inspection	21/08/2023		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Narender Satya Garg		
10	Year of construction	2007		
11	Applicant letter No.	Outdoor diary no 4088 dated 24-07-2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL-2016 Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			MR (old case)
	• Road width	Associable	10 feet	-NA-
	• Gate width	-NA-	2.10 mtr	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	01 No	02 Nos Provided	MR
	➤ Basement floor.	01 No	02 Nos Provided	MR
	b) Width of Staircase			
	➤ Upper floors	1.50 mtr	1.50m & 1m	MR
	➤ Basement floor	1.50 mtr	1.50m & 1m	MR
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	01 No	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	-NA-	-NA-	-NA-
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust Fan	MR
	• Upper floors	12 ACPH	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	Required	12 Nos	MR
	• Types	ABC / CO2	Co2 & ABC	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	01 No	Provided	MR

N/29

	<ul style="list-style-type: none"> Length of hose-reel hose. 	30 mtr	Provided	MR
	<ul style="list-style-type: none"> Nozzle Diameter 	5 mm	Provided	MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location of Main Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location of Repeater Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Alternate source of power 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hooter's location 	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper floors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	Required	Provided	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	-NA-	01 No	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	01 No	-NA-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Head of main pump. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Number of main pumps. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Jockey Pump output. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Jockey Pump head. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Standby Pump output. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Standby Pump head. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Auto Starting/Manual Stopping. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pump house access. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. 	450 LPM	450 LPM	MR
	<ul style="list-style-type: none"> Head of pump. 	40 mtr	40 mtr	MR
	<ul style="list-style-type: none"> Power supply. 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto starting of pump. 	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Draw-off connection. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fire Service Inlet. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Access to tank. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Overhead tank capacity. 	5,000 Ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Communication in lift car. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fireman's switch. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Lift signage. 	-NA-	-NA-	-NA-
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	-NA-	-NA-	-NA-


N/30

• Location		-NA-	-NA-	-NA-
19.	Fire Control Room.	-NA-	-NA-	-NA-
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection and 3rd floor not for use undertaking enclosed.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DPS/MS/School/2020/SZ/109 dated 12-03-2020 for B + G + 2 Upper Floor, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name: Sh. Rajesh Kumar
 Design: ADO (BCP)

DO (SD)

mevll
24/8

CFD Meegh
23/8/2023

Director Meegh
23/8/2023

A DO/AD

As approved, F.T. letter is put up for your signature @

Meegh
24/8

CFD Meegh
28/8/2023

FPW