

C-127

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/School/579

Dated: 24/08/2023

FIRE SAFETY CERTIFICATE

Certified that the building of **Prudence Sr. Sec. School** located at, **Sector - 22, Dwarka, New Delhi - 110075** comprised of Basement, Stilt+ 4 UFs was issued FSC vide letter No. F6/DFS/MS/School/2020/SZ/295, dated 19/08/2020. The premises was re inspected by the officers concerned of this department on 16/08/2023 in the presence of Sh. Rajesh (Admin officer) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Educational" with effect from 24/08/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/08/2023 at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service.

Copy to:

1. The Principal, Prudence Sr. Sec. School, Sector - 22, Dwarka, New Delhi - 110075.
2. Directorate of Education Old Secretariat Delhi - 110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/31

INSPECTION REPORT

1. Name & address of the building: Prudence Sr. Sec. School located at, Sector - 22, Dwarka, New Delhi - 110075.
2. Type of Occupancy : Educational (Basement, Stilt+4 UFs)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2020/SZ/295, dated 19/08/2020
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2011/535, dated 24/03/11
6. Date of inspection : 16/08/2023
7. Name of the Inspecting Officer : DO/SW & ADO (DWK)
8. Name and designation of Officer
from the building side: Sh. Rajesh (Admin officer)
9. Year of Construction : 2011-12
10. Applicant's letter No. : Nil, dated 02/08/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As per directive issued on 24/03/2011	Provided at site	Remarks MR/NMR
1.	Access of building			MR
	Road width	30 mtr	Provided	MR
	Gate width	06 mtr	Provided	MR
	Width of internal road	06 mtr	5.8m to 6m	MR(Being old case)
2.	Number, width, Type & Arrangements of exits			
	Number of staircases		Provided	MR
	Upper floors	04 Nos.		MR
	Basements	04 Nos.	Provided	MR
	Width of staircases			MR
	Upper floors	1.5 mtr each	Provided	MR
	Basements	1.5 mtr each	Provided	MR
	Protection of exits			MR
	Fire check door	Required	Provided	MR
	Pressurization	NA	NA	NA
	No of continuous staircase to terrace	04 Nos.	Provided	MR
	Width Of Corridor	1.5 mtr	Provided	MR
	Door Size	01 mtr & 1.2 mtr	0.92m to 1m	MR (Old case)
3.	Compartmentation			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire Rating of shaft door	NA	NA	NA
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	Basements	30 a/c per hour	Provided	MR
	Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	Total numbers	08 nos.each floor	Provided	MR
	Types	ABC & CO ₂	ABC & CO ₂	MR
	ISI marking	ISI marked	ISI marked	MR
6.	First - Aid Hose Reels .			
	Total numbers on each floor	04 Nos.	Provided	MR
	Length of hose reel hose	30 mtr	Provided	MR
	Nozzle diameter	05 mm	Provided	MR

7.	Automatic fire detection and alarming system			
	Type of detectors	NA	NA	NA
	Location of Main Panel	NA	NA	NA
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters' Location	Near Staircase	Provided	MR
8.	MOEFA	Required	Functional	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	Basements	Required	Provided	MR
	Upper Floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	Size of riser/down-comer	150 mm	Provided	MR
	Number of hydrants per floor	04 Nos.	Provided	MR
	Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	Total number of hydrants	NA	Provided	NA
	Hose Box	NA	Provided	NA
13.	Pumping Arrangements:			
	Ground Level			
	Discharge of main pump	NA	NA	NA
	Head of main pump	NA	NA	NA
	Number of main pumps	NA	NA	NA
	Jockey pump out put	NA	NA	NA
	Jockey pump head	NA	NA	NA
	Standby Pump out put	NA	NA	NA
	Standby Pump Head	NA	NA	NA
	Auto starting/Manual stopping	NA	NA	NA
	Pump House Access	NA	NA	NA
	Terrace level			
	Discharge of pump	2X900 lpm	Provided	MR
	Head of the pump	40 mtr	Provided	MR
	Power supply	Required	Provided	MR
	Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	Under ground tank capacity	NA	2,00,000 ltr	NA
	Draw off connection	NA	Provided	NA
	Fire service inlet	NA	Provided	NA
	Access to tank	NA	Provided	MR
	Overhead Tank capacity	25,000 ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of lift lobby	NA	NA	NA
	Communication in lift Car	Required	Provided	MR
	Fireman's Grounding Switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	Total area	NA	NA	NA
	Location	NA	NA	NA

19.	Fire control room		
	Detector system panel	NA	NA
	Flow Switch Panel	NA	NA
	PA System Panel	NA	NA
	Battery backup	NA	NA
	Building Floor Plans	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 , Fire extinguisher provided near electric panel
			MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/School/2020/SZ/295, dated 19/08/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Sh. Vedpal
 Signature of the Inspecting Officer
 Name: Sh. Vedpal
 Designation: DO/SW

Udai Vir Singh
 Signature of the Inspecting Officer
 Name: Udai Vir Singh
 Designation: ADO/DWK

CFO (S2)
21/8/2023
Director
22/8/23

ADO (Dwarka)
23/8/23

Sir PT letter is put up for Sing ple

Director
23/8/23
me

Udai Vir Singh
23/8/23