

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No. F.6/DFS/MS/School/2023/SZ/605

Dated: 31/08/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **Chinmaya Vidyalaya** located at Vasant Vihar, New Delhi comprised of two Blocks, New Blocks- Basement (Sunken), ground plus three upper floors & old Block- Ground plus Three upper floors owned/occupied by Chinmaya Vidyalaya was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2020/SZ/274 dated 10/08/2020. The said premises was re-inspected by officer concerned of this department on 22/08/2023 in presence of Mr. Raghbir Singh and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 31/08/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 31/08/2023 at New Delhi by

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Principal, Chinmaya Vidyalaya located at Vasant Vihar, New Delhi.
2. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept unlocked and free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of BBL /NBC Part- IV.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."



N/32

INSPECTION REPORT				
1	Name & Address of the Building	Chinmaya Vidyalaya Vasant Vihar, New Delhi		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Old Block- Ground plus three upper floor, New Block- Basement (Sunken) Ground + 03 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2020/SZ/274 dated 10/08/2020		
6	Fire Safety Directives Letter No	F6/DFS/MS/98/2257 dated 12/11/1998 F6/DFS/MS/BP/2011/551 dated 28/03/2011		
7	Date of Inspection	22.08.2023		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Raghbir Singh		
10	Year of construction	1984 & 2002		
11	Applicant letter No.	Ref:- CV/FIRE/NOC/23-24/001 dated 24-02-2023		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Required	05 mtr	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a. Number of Staircase</b>			
	➤ Upper floors.	02 Nos	05 Nos	MR
	➤ Basement floor.	02 Nos	02 Nos	MR
	<b>b. Width of Staircase</b>			
	➤ Upper floors	1.50 mtr	1.33m, 1.33m, 1.30m, 1.51m & 1.37m	MR Old case
	➤ Basement floor	1.50 mtr	1.30m & 1.30m + 01 exit	MR Old case
	<b>c. Protection of exits</b>			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	<b>d. No. of continuous staircase to terrace</b>	Required	05 Nos	MR
	<b>e. Width of corridor</b>	NA	NA	NA
	<b>f. Door size</b>	1.0 mtr	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4.	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	NA	NA	NA
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	49 Nos	Provided	MR
	• Types	ABC / Co2	ABC- /Co2	MR
	• ISI Marking	Required	Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	01 No	02 Nos	MR



M/33

	<ul style="list-style-type: none"> <li>Length of hose-reel hose.</li> <li>Nozzle Diameter</li> </ul>	30 mtr 5 mm	provided provided	MR MR
7	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	<b>MOEFA</b>	NA	Provided	NA
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> <li>Sprinkler above false ceiling</li> </ul>	Required NA NA	Provided NA NA	MR NA NA
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	100mm 02 Nos 02 Nos	Provided Provided Provided	MR MR MR
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	NA NA	Provided Provided	NA NA
13.	<b>Pumping arrangements.</b>			
	<b>A. Ground Level</b>			
	<ul style="list-style-type: none"> <li>Discharge of main pump.</li> <li>Head of main pump.</li> <li>Number of main pumps.</li> <li>Jockey Pump output.</li> <li>Jockey Pump head.</li> <li>Standby Pump output.</li> <li>Standby Pump head.</li> <li>Auto Starting / Manual Stopping.</li> <li>Pump house access.</li> </ul>	NA NA NA NA NA NA NA NA	1620 LPM 70m 01 No 180 LPM 70m NA NA NA	NA NA NA NA NA NA NA NA
	<b>B. Terrace Level</b>			
	<ul style="list-style-type: none"> <li>Discharge of pump.</li> <li>Head of pump.</li> <li>Power supply.</li> <li>Auto starting of pump.</li> </ul>	900 LPM 40 mtr Required Required	900 LPM Provided Provided Provided	MR MR MR MR
14.	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity.               <ul style="list-style-type: none"> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> <li>Access to tank.</li> </ul> </li> <li>Overhead tank capacity.</li> </ul>	50,000 ltrs Required Required Required Required	Provided Provided Provided Provided 10,000 ltr	MR MR MR MR MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> <li>Pressurization of lift lobby.</li> <li>Communication in lift car.</li> <li>Fireman's switch.</li> <li>Lift signage.</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
17.	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	NA NA	NA NA	NA NA

N/34

19.	<b>Fire Control Room.</b>			
	• Detector system panel.	NA	NA	NA
	• Flow switch panel.	NA	NA	NA
	• PA system panel.	NA	NA	NA
	• Battery backup.	NA	NA	NA
	• Building floor plan.	NA	NA	NA
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			NA
<p>The fire protection system provided in the building were randomly checked and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2020/SZ/274 dated 10/08/2020, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p>				
<p><i>manj</i> Signature of the Inspection Officer Name: Sh. Manoj Kumar Sharma Design: DO (South)</p>		<p><i>Sh. Rajesh Kumar</i> Signature of the Inspecting Officer Name: Sh. Rajesh Kumar Design: ADO (BCP)</p>		

CFO (HO)

*Manoj*  
25/8/2022

*Director*

*28/8/22*

*ADP/BCP*

As approved, F.T. letter is put up  
for your signature pl

*1/1/28/8*

*Director*  
*34/8/22*  
*u*