



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/School/2023/NDZI 602

Dated: 31/08/2023

FIRE SAFETY CERTIFICATE

Certified that Kanhaiya Public School running at ground and first floor building comprised of ground, first and second floor at West Karawal Nagar, Delhi-110090, owned/occupied by Kanhaiya Public School was issued FSC vide letter No. F.6/DFS/MS/School/2019/NDZI/239 dated 30/01/2019. The premises was re-inspected by the officer concerned of this department on dated 02/08/2023 in the presence of Mrs. Trinetra Parihar (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. Circular No. 262-362 dated 17/01/2005 issued by the Director of Education and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from 31-08-2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 31-08-2023 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

To:-

1. The Principal
Kanhaiya Public School at West Karawal Nagar, Delhi-110090
2. The Dy. Director of Education,
B-Block, Yamuna Vihar, Delhi-110053

Conditions for the validity of Fire Safety Certificate

1. Fire Safety Certificate is valid for ground and first floor only. Applicant has submitted an undertaking dated 07/08/2023 that he will not use second floor for school purpose failing which this FSC should be treated null & void.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

N/4

1. Name & address of the building : Kanhaiya Public School
West Karawal Nagar, Delhi-110090
2. Building is comprised of : Ground plus two upper floors
(School is running on ground & first floor only)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/DFS/MS/School/2019/NDZ/239 dt 30/01/2019
6. Fire Safety directive letter No : Circular No. 262-362 dated 17/01/2005 issued by DoE
7. Date of Inspection : 02/08/2022
8. Name of the Inspecting officers : ADO Deepak Kumar
9. Name and designation of officer
from the building side : Mrs Trinetra Parihar (Principal)
10. Year of Construction : 1995
11. Applicant's letter No : Nil Dated- 12/07/2023

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			MR ✓
	• Road width	06 mtr.	06 mtr.	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	01 nos	02 nos	MR ✓
	• Upper floor	N/A	N/A	N/A
	• Basement			
	b. Width of Staircases	1.50 mtr	1.40 mtr & 0.88 mtr	MR ✓
	• Upper floor	N/A	N/A	N/A
	• Basement			
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization			
	d. No. of Continuous Staircases to Terrace	01 no.	01 no.	N/A
	e. Width of corridor	1.50 mtr	1.60 mtr	MR ✓
	f. Door Size	01 mtr.	1.16 mtr.	MR ✓
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	04 nos.	06 nos.	MR ✓
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

R. A

4/5

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of Main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	220 Lpm	220 Lpm	MR
	• Head of the pump	40 mtr	40 mtr	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	2500 Ltr.	2500 Ltr.	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft • Pressurization of lift lobby • Communication in lift car • Firemen's grounding switch • Lift signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building floor plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

Note:- Building is ground, first and second floor only but applicant has submitted an undertaking dated 07/08/2023 placed at C-23 that he will not use second floor for school purpose.

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule the FSC issued vide letter No. F.6/DFS/MS/School/2019/NDZ/239 dt 30/01/2019 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Deepak 07/08/2023.
 Signature of the Inspecting Officer
 Name :- Deepak Kumar
 Designation :- A.D.O (Shd)

~~DO(E)~~ P.L. speak.

Approved
 12/08/2023

~~ADOL Shalokh~~

Sir,

Spoken and file re-submit
 for your approval pl

~~DO(E)~~

Submitted for approval pl.

Approved
 21/8/2023

P.T.O.