



No.F6/DFS/MS/School/SZ/2023

420

Dated: 02/09/2023

**FIRE SAFETY CERTIFICATE**

Certified that the M/s New Nalanda Public School located at Street No. 17, Molarband Extension, Badarpur New Delhi-44, comprised of Ground + 2 upper floors, owned & occupied by New Nalanda Public School has complied with the fire prevention and fire safety requirements in accordance with the Circular no. 262-232 dated-17/01/2005 issued by the Directorate of Education and verified by officer concerned of Delhi Fire Service on 31.08.2023 in the presence of Mr. Sanjay Singh (Manager) and found that the building/premises (Ground + 2 upper floors) is fit for occupancy of Group B "Educational Building" with effect from 02/09/2023 for a period of three years, subject to conditions printed below.

Issued on...02/09/2023...at New Delhi by.

(Atul Garg)

Director

Delhi Fire Service

At 31/08/23

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Principal, M/s New Nalanda Public School located at Street No. 17, Molarband Extension, Badarpur New Delhi-44.

**Conditions for the validity of Fire Safety Certificate:-**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1	Name & address of the building	M/s New Nalanda Public School located at Street No. 17, Molarband Extension, Badarpur New Delhi-44.		
2	Building is comprised of	Ground + 02 upper floors		
3	Type of occupancy	Group B -Educational Building		
4	Type of case	New		
5	Details of previous FSC	Nil		
6	Fire safety direction letter no.	D.O.E Circular 262-362 dated-17/01/2005		
7	Date of inspection	31.08.2023		
8	Name of the inspecting officers	Rajesh Kumar Shukla ADO (M. Road)		
9	Name of the designation of officer from the building side	Mr. Sanjay Singh (Manager)		
10	Year of construction	1997		
11	Applicant's letter no.	Email dated 24.08.2023		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per D.O.E Circular dated 17.01.2005	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
A	Road width	Accessible	Accessible	MR
B	Gate width	NA	NA	NA
C	Width of internal road	NA	NA	NA
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
A	Number of staircases			
a	Upper floor	02 nos.	02 nos.	MR
b	Basement	NA	NA	NA
B	Width of staircases			
a	Upper floor	Required (2 exits)	1.11 mtrs & 1.06 mtrs	MR
b	Basement	NA	NA	NA
C	Protection of exits			
a	Fire check door	NA	NA	NA
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	2 nos.	2 nos.	MR
E	Width of corridor	NA	NA	NA
F	Door size	1.0 mtrs. (class room)	Provided	MR
3	<b>Compartmentation:</b>			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	NA	NA	NA
C	Fire rating of shaft door	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA
4	<b>Smoke Management System:</b>			
A	Basement	NA	NA	NA
B	Upper floor	Mechanical/Natural	Natural	MR

✓

8/11/23

<b>5.</b>	<b>Fire Extinguisher:</b>				
	<b>A</b>	Total numbers	08 nos.	08 nos.	MR
	<b>B</b>	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	<b>C</b>	ISI marking	Required	Provided	MR
<b>6</b>	<b>First-Aid-Hose Reel:</b>				
	<b>A</b>	Total numbers of each floor	01 no.	01 no.	MR
	<b>B</b>	Length of hose reel hose	30 mtrs	30 mtrs	MR
	<b>C</b>	Nozzle diameter	5 mm	5 mm	MR
<b>7</b>	<b>Automatic Fire Detection and Alarming System:</b>				
	<b>A</b>	Type of detectors	NA	NA	NA
	<b>B</b>	Location of main panel	NA	NA	NA
	<b>C</b>	Location of repeater panel	NA	NA	NA
	<b>D</b>	Alternate source of power	NA	NA	NA
	<b>E</b>	Hooters	NA	NA	NA
<b>8</b>	<b>MOEFA:</b>				
			NA	NA	NA
<b>9</b>	<b>Public Address System:</b>				
			NA	NA	NA
<b>10</b>	<b>Automatic Sprinkler System:</b>				
	<b>A</b>	Basement	NA	NA	NA
	<b>B</b>	Upper floor	NA	NA	NA
	<b>C</b>	Sprinkler above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants:</b>				
	<b>A</b>	Size of riser/down-comer	NA	NA	NA
	<b>B</b>	Number of hydrants per floor	NA	NA	NA
	<b>C</b>	Hose box	NA	NA	NA
<b>12</b>	<b>Yard Hydrants:</b>				
	<b>A</b>	Total number of hydrants	NA	NA	NA
	<b>B</b>	Hose box	NA	NA	NA
<b>13</b>	<b>Pumping Arrangements:</b>				
<b>1</b>	<b>Ground level</b>				
	<b>A</b>	Discharge of main pump	NA	NA	NA
	<b>B</b>	Head of main pump	NA	NA	NA
	<b>C</b>	Number of main pumps	NA	NA	NA
	<b>D</b>	Jockey pump out put	NA	NA	NA
	<b>E</b>	Jockey pump head	NA	NA	NA
	<b>F</b>	Standby pump out put	NA	NA	NA
	<b>G</b>	Standby pump head	NA	NA	NA
	<b>H</b>	Auto starting /manual stopping	NA	NA	NA
	<b>I</b>	Pump house access	NA	NA	NA
<b>2</b>	<b>Terrace Level</b>				
	<b>A</b>	Discharge of pump	220 LPM	220 LPM	MR
	<b>B</b>	Head of the pump	40 mtrs	40 mtrs	MR
	<b>C</b>	Power supply	Required	Provided	MR
	<b>D</b>	Auto starting of pump	Required	Provided	MR

M/s New Nalanda Public School located at Street No. 17, Molarband Extension, Badarpur New Delhi-44

2/6

14	<b>Captive Water Storage for Fire Fighting:</b>			
A	Underground tank capacity	NA	NA	NA
B	Draw-off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
D	Access to tank	NA	NA	MR
E	Overhead tank capacity	2,500 ltrs	Provided	MR
15	<b>Exit Signage:</b>			
16	<b>Provision of Lifts:</b>			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Firemen's grounding switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17	<b>Standby Power Supply:</b>			
18	<b>Refuge Area:</b>			
A	Total area	NA	NA	NA
B	Location	NA	NA	NA
19	<b>Fire Control Room:</b>			
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	PA system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
20	<b>Special Fire Protection systems for protection of special Risks, if any:</b>			

**Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).**

**Note:- Note:-** As stated in letter no.F6/DFS/MS/2007/573, the shortcomings have been issued as per Directorate of Education circular no. 262-362 in accordance with Rule 35(6) of DFS Rules 2010 inspections shall be conducted as per the same circular. Accordingly the present inspection has been conducted as per Directorate of Education circular no. 262-362 dated 17.01.2005, Wherein 6.0 meter road accessibility for fire engine is not a mandatory requirement. The school building is about 20-30 meters from main road (width more than 6.0 meter) and is accessible for small water tender by an approach road of 4.30 meters width.

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

If agreed to the note above & in view the substantial compliance of the minimum standards on fire prevention and fire safety measure as required in Directorate of Education Circular 262-362 dated-17/01/2005, it is recommended to grant Fire Safety Certificate to the school.

Accordingly, letter is put up for approval & signature Please.

Signature of the Inspecting Officer  
Name Rajesh Kumar Shukla  
Designation ADO (M. Road)

DO (SD)  
merse  
31/8/23  
CP  
1/9/2023

Amey M M