



FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/SZ/2023/ 421

Dated: 04/09/2023

FIRE SAFETY CERTIFICATE

Certified that the building of Upkari CGHS Ltd. Located at Plot No-09, Sector-12, Phase-1, Dwarka, New Delhi-110075 having 04 blocks, comprised of Basement + Ground/Stilt +Six/Seven UFs was issued No Objection Certificate for occupancy of the building by this department vide letter No. F6/DFS/MS/CGHS/2002/1525, dated 11/09/2002. The premise was re inspected by the officer concerned of this department on 26/08/2023 in the presence of Sh. Inderjeet Singh (Secretary) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Residential Building" Group A-4 with effect from 04/09/2023 for a period of **five years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/09/2023 at New Delhi by.


 (Abul Garg)
 Director
 Delhi Fire Service.

Copy to:

1. The President, Upkari CGHS Ltd. Located at Plot No-09, Sector-12, Phase-1, Dwarka, New Delhi-110075.
2. The Joint Director (Building) DDA, Vikas Sadan, INA, Delhi-110023.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

218
INSPECTION REPORT

1. Name & address of the building: Upkari CGHS Ltd. Located at Plot No-09, Sector-12, Phase-1, Dwarka, New Delhi-110075.
2. Type of Occupancy : Residential Building "A" (Apartment)
3. Type of Case : Renewal (04 BL =Basement+Ground/Stilt +Six/Seven UFs)
4. Details of previous NOC : F6/DFS/MS/CGHS/2002/1525, dated 11/09/2002
5. Fire Safety directives Letter No. : F6//DFS/MS/CGHS/97/1445, dated 08/10/1997 & F6//DFS/MS/CGHS/98/994, dated 25/05/1998
6. Date of inspection : 26/08/2023
7. Name of the Inspecting Officer : Sh. Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Inderjeet Singh (Secretary)
9. Year of Construction : 2001
10. Applicant's letter No. : CGHS/Fire Deptt./2023-24/01, dated-21/08/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As Per- directive	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 mtrs	Provided	MR
	• Gate width	6 mtrs	Provided	MR (old case)
	• Width of internal road	6 mtrs	5.8 to 6m	MR(Old case)
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1 no. each BL	Provided(Two Blocks Interconnected at Terrace & 4th,5th,6th floors)	MR
	• Basements	2 Nos.	Provided	MR
	b. Width of staircases			
	• Upper floors	1.25 mtr each	115cm	MR (Being old case)
	• Basements	1.25 m	115m	MR (Being old case)
	c. Protection of exits			
	• Fire check door	SCD	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	01 each block	Provided	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	Exhaust Fan Provided	N/A
	• Upper floors	N/A	Natural Ventilation	N/A

[Handwritten Signature]

119

5.	Fire Extinguishers			
	• Total numbers	2 nos. each floor	Provided	MR
	• Types	CO ₂ & ABC	CO ₂ , ABC, Water Co2	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01 No. each Floor	Provided	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	1 each block	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level	N/A	N/A	N/A
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 lpm each block	Provided	MR
	➤ Head of the pump	40 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	2,00,000 ltrs	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltr each block	Provided	MR
15	Exit Signage	Required	Provided	MR

[Handwritten signature]

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set 60 KVA	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.
 In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F6/DFS/MS/CGHS/2002/1525, dated 11/09/2002 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended

Signature of the Inspecting Officer
 Name Vijay Vir Singh
 Designation Asst. Commr

[Signature]
 29/8/23

CFO(S2)
[Signature]
 29/8/2023
 Director

Ray Singh
 Sir PP letter to put up for sig pbr
[Signature]
 21/9/23
 DIRECTOR