

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2023/ 614

Dated: 04/09/2023

FIRE SAFETY CERTIFICATE

Certified that the Govt. Co-ed. Sarvodaya Vidyalaya, Sector-2, Rohini, Delhi-110085, (School ID-1413006), comprised of 02 Blocks, Ground + 03 upper floors owned/ occupied by Govt. Co-ed. Sarvodaya Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on dated 27.07.2023 in the presence of Sh. Virender Kumar (Principal) and that the building/ premise is fit for occupancy Group B Educational with effect from 04/09/2023. for a period of three years, in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on04/09/2023.....at New Delhi by

(Atul Garg)
DIRECTOR

Ph; 011-23414000

DU
 OY

Copy to:

1. The Principal, Govt. Co-ed. Sarvodaya Vidyalaya, Sector-2, Rohini, Delhi-110085. (School ID-1413006).
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.
3. The Executive engineer (E), PWD, Education Electrical Edn. 1 Division (N) ITI Campus Pusa, New Delhi-110012.

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Fire+Safety+Acts+and+Rules/> <http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Forms>

N/18

INSPECTION REPORT

1. Name & address of the building : Govt. Co-ed. Sarvodaya Vidyalaya, Sector-2, Rohini, Delhi-110085
2. Type of Occupancy : Educational (School ID-1413006)
3. Type of Case : New Case (2 Blocks, Ground + 03 upper floors)
4. Details of Previous NOC : NA
5. Fire Safety directives letter No : NBC Part-IV.
6. Date of inspection : 27.07.2023
7. Name of Inspecting Officer : Sh. Ajay Kumar Sharma (ADO Rohini)
8. Name and designation of officers
From the building side : Sh. Virender Kumar (Principal)
9. Year of Construction : 2023
10. Applicant's letter No. : Online e-mail dated 05.06.2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6m	Provided	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Block-A-02 Block-B-03	02 & 01 ramp 03	MR MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	Block-A-1.5m Block-A-1.5m	Blk-A- 2 x 1.60m & 01 ramp-1.60m Blk-B- 3 x 1.60m	MR MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Block-A 02 Block-B-03	02 03	MR MR
	e. Width of Corridor	Block-A 1.5m Block-B-1.5m	1.6m 1.6m	MR MR
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	Block-A-26 Block-B-34	Block-A-104 Block-B-76	MR MR
	• Types	ABC/CO2	ABC-52/CO2-52 ABC-38/CO2-38	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Block-A-03 Block-B-03	Provided Provided	MR MR

My

+

	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	30mm	Provided	MR
		5m	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		Block-A-450lpm Block-B-450lpm	Block-A-2 x 450lpm Block-B-2 x 450lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		Block-A-10,000ltr Block-B-10,000ltr	2 x 5,000ltr 2 x 5,000ltr	MR
				MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

Amj

X

