



C-69

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/EH/WZ/2023/276

Dated: 01/09/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s. Punjab Grill (A Unit of Lite Bite Foods Pvt. Ltd.), located at Unit G-05, Ground floor, Aggarwal Millenium Tower 1, Plot No. 1, 2, 3, Netaji Subhash Place, New Delhi – 110034, in a building comprised of 02 Blocks (LG + G + 10 upper floors) & (LG. + G + 05 upper floors) was issued FSC vide this dept letter no. F6/DFS/MS/EH/2017/1482 dated 10/10/2017 (Issued to Pizza Hut in same shop) & FSC to building is issued vide letter No. - F6/DFS/MS/WZ/2021/199 dated 31/03/2021. The premises was re-inspected by the officer concerned of this department on 28/08/2023 in the presence of Sh. Harish Kumar and found that the said building/premises have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire service Rules, 2010 and that the said building/premises is fit for occupancy class "Assembly" (Group – D) and validity upto 31/03/2026 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 conditions printed overleaf.

Issued on 01/09/2023 at New Delhi by.


(Atul Garg)
Director
 31/8
 30/8/2023

Copy to: -

1. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. **Email-ID:- adlcp.lic-dl@nic.in**
2. The owner/ Occupier, M/s. Punjabi Grill (A Unit of Lite Bite Foods Pvt. Ltd.), located at Unit G-05, Ground floor, Aggarwal Millenium Tower 1, Plot No. 1 2 3, Netaji Subhash Place, New Delhi – 110034.
3. The Dy. Health Officer, Keshav Puram Zone, MCD, New Delhi.

INSPECTION REPORT

1. Name & address of the building	Punjab Grill (A Unit of Lite Bite Foods Pvt. Ltd.) Located at Unit G 05, Ground floor, Aggarwal Millenium Tower 1, Plot No. 1 2 3, Netaji Subhash Place, New Delhi - 110034.
2. Type of Occupancy	Eating House /Assembly Occupancy
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/EH/2017/1482 dated 10/10/2017 (Earlier FSC issued namely Pizza Hut A unit of Devyani international Ltd.
5. Fire Safety directives letter No	FSC issued to the building
6. Date of inspection	22/08/2023
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Harish Kumar
9. Year of Construction	2003 (As per MHA Portal)
10. Applicant's letter No.	Online Application ID No. 2023080514061 dated 07/08/2023

The Said Restaurant is running at Ground floor in a Building Comprised of 02 Blocks (LG + G + 10 upper floors) & (LG + G + 05 upper floors) was issued FSC vide this dept letter no. F6/DFS/MS/WZ/2021/199 dated 31/03/2021.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	NA	NA	NA
	g. Door Size	Old Case	Old Case	Old Case
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Provided	MR
5	Fire Extinguishers			
	• Total numbers	05	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

✍

SH

6	First-Aid Hose Reels. (Common with the Building)			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NR	NR	NR
10	Automatic Sprinkler System.			
	• Basement	Required in LG	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants Common with the Building			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements. Common with the Building			
	• Ground Level			
	➢ Discharge of main Pump	NR	Common with the Building	MR
	➢ Head of Main pump	NR	Common with the Building	MR
	➢ Number of main pumps	NR	Common with the Building	MR
	➢ Jockey Pump out put	NR	Common with the Building	MR
	➢ Jockey pump head	NR	Common with the Building	MR
	➢ Standby Pump out put	NR	Common with the Building	MR
	➢ Standby Pump Head	NR	Common with the Building	MR
	➢ Auto Starting/ Manual stopping	NR	Common with the Building	MR
	➢ Pump House Access	NR	Common with the Building	MR
	• Terrace level			
	➢ Discharge of pump	900lpm	Common with the Building	MR
	➢ Head of the pump	40 m	Common with the Building	MR
	➢ Power Supply	Required	Common with the Building	MR
	➢ Auto Starting of pump	Required	Common with the Building	MR
14	Captive Water Storage for fire fighting. Common with the Building			
	• Underground tank capacity	NA	2,00,000ltr	MR
	➢ Draw-off connection	NA	Provided	MR
	➢ Fire service inlet	Required	Provided	MR
	➢ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000ltr	30,000ltr Provided	MR
15	Exit Signage.	Required	Provided	MR

22/

16 Provision of Lifts.				
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18 Refuge Area.				
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19 Fire Control Room				
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2017/1482 dated 10/10/2017 (Earlier FSC issued namely Pizza Hut A unit of Devyani international Ltd.) renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

O/ADO/MN
23/8/23

~~Dy CPO (W/2)~~

~~Sarabjeet Singh~~
23/8/2023

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

LFO... 10.50
24/8/2023

~~M.K. CHATTOPADHYAY~~
23/8

~~CFO~~ Put up FSC as per new/current policy

~~28/8/2023~~

~~Dy CPO (W/2)~~

~~23/8~~

~~ADO (MN)~~ Sir
fresh F.S.C as directed is pu
up for you sj. Ms.
30/8/2023