



C-78

75  
जाज़ादी  
अमृत महोत्सव

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**

No. F6/DFS/MS/WZ/EH/2023/279

Dated: 01/09/2023

**FIRE SAFETY CERTIFICATE**

Certified that the M/s. Sagar Ratna Restaurant Pvt. Ltd., Located, at Ground Floor, B-2/1, Ashok Vihar, Phase-II, New Delhi – 110052, in a building comprised of Ground + 03 Upper floors. Owned/Occupied by M/s. Sagar Ratna Restaurant Pvt. Ltd., FSC was already issued by this department Vide letter no. F.6/DFS/MS/WZ/2020/63 dated 12/03/2020. The Premises was re-inspected by the officer concerned of this department on 22/08/2023 in the presence of Sh. Yogesh (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the said floor is fit for occupancy class "Assembly" (Group- D) (Ground Floor Only) with effect from 01/09/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions printed overleaf.

Issued on 01/09/2023 at New Delhi by.

(Atul Garg)  
Director

30/8/2023

Copy to: -

1. The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> floor, Police Station, Defence Colony, New Delhi. **Email-ID:- [addlcp.lic-dl@nic.in](mailto:addlcp.lic-dl@nic.in)**
2. M/s. Sagar Ratna Restaurant Pvt. Ltd., Located, at Ground Floor, B-2/1, Ashok Vihar, Phase-II, New Delhi – 110052. (Online ID No.- 2021112327000 dated 14/08/2023)
3. The Dy. Health Officer, Keshav Puram Zone, MCD, New Delhi.

**INSPECTION REPORT**

1. Name & address of the building	M/s. Sagar Ratna Restaurant Pvt. Ltd., Located at Ground Floor, B-2/1, Ashok Vihar, Phase-II, New Delhi – 110052.
2. Type of Occupancy	Assembly (Restaurant)
3. Type of Case	Renewal
4. Details of previous NOC	F.6/DFS/MS/WZ/2020/63 dated 12.03.2020
5. Fire Safety directives letter No	N/A
6. Date of inspection	22/08/2023
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Yogesh (Manager)
9. Year of Construction	1990 (As per MHA Portal)
10. Applicant's letter No.	Online Application ID No. 2021112327000 dated 14/08/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 m	Provided	MR
	• Gate width	4.5m	Directly accessible from the main road	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	NA	Restaurant running at GF	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	Restaurant running at GF	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	NA	NA	NA
	g. Door Size	Old Case	1.15, 0.80 mt	MR, old case
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	08 nos.	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR




6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	NR	NR	NR
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NR	NR	NR
	➤ Head of Main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey Pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/ Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	450lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 ltrs	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR

6 Provision of Lifts.					
	•	Pressurization of Lift Shaft	NA	NA	NA
	•	Pressurization of Lift lobby	NA	NA	NA
	•	Communication In lift Car	NA	NA	NA
	•	Fireman's Grounding Switch	NA	NA	NA
	•	Lift Signage	NA	NA	NA
17	Standby power supply		Required	Provided	MR
18 Refuge Area.					
	➤	Total Area	NA	NA	NA
	➤	Location	NA	NA	NA
19 Fire Control Room					
	•	Detector System Panel	NA	NA	NA
	•	Flow Switch Panel	NA	NA	NA
	•	PA System Panel	NA	NA	NA
	•	Batter backup	NA	NA	NA
	•	Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:		NA	NA	NA

o/ADO/MN  
21/08/2023

The fire protection system provided in the building were checked and found functional at the time of inspection. The shortcomings issued by this department vide letter No. F.6/DFS/MS/EH/WZ/2023/59 dated 03/02/2023 & F6/DFS/MS/WZ/EH/2023/412 dated 26/07/2023 has been complied.

In view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/WZ/WZ/2020/63 dated 12/03/2020, renewal under rule 35 of the Delhi Fire Service Rules 2010, is recommended.

*(Signature)*  
22/8/2023

*(Signature)*  
22/8/2023  
Signature of the Inspecting Officer  
Name: - Sarabjeet Singh  
Designation: - ADO (MN)

ICFO/.../05/1/2023  
Dated...24/6/2023

*(Signature)*  
M.K. CHATTOPADHYAY  
25/8/2023

*(Signature)*  
26/8/23

DCP/MKC

put up F.T.  
*(Signature)*  
28/8

ADO (MN)