



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No: F.6/DFS/MS/School/WZ/2023/ 613

Dated: 04/09. /2023

FIRE SAFETY CERTIFICATE

Certified that the S.B.M. Senior Secondary School, located at Shivaji Marg, New Delhi – 110015, in a building comprised of ground plus three upper floors, Owned/occupied by S.B.M. Senior Secondary School, was issued FSC vide letter No. F6/DFS/MS/School/2020/WZ/442 dated 22/10/2020. The premises was re-inspected by the officer concerned by this department on 23/08/2023 in the presence of Dr. Preeti Shukla (Principal) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by DOE Circular No.- 262-362 dated 17/01/2005 and that the premises is fit for occupancy class 'Educational' (Group-B), with effect from...for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to the compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 Condition mentioned below.

04/09/2023
Issued on...at New Delhi.

(Atul Garg)
Director

Copy to: -

1. The Principal M/s S.B.M. Senior Secondary School, located at Shivaji Marg, New Delhi-110015.
2. Director of Education, Old Secretariat, New Delhi-110054.



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

2/23
INSPECTION REPORT

1. Name & address of the building	SBM Senior Secondary School, Shivaji Marg, New Delhi - 110015.
2. Type of Occupancy	Educational (Ground + 03 upper floor)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/School/2020/WZ/442 dated 22/10/2020
5. Fire Safety directives letter No	DOE Circular No.- 262-362 dated 17/01/2005
6. Date of inspection	23/08/2023
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Dr. Preeti Shukla (Principal)
9. Year of Construction	2000 (As per prev. inspection report dtd.- 08/10/2020)
10. Applicant's letter No.	Letter no. SB/F-39/23/238 dated 17/08/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mtr	2 mtr X 2 Provided	MR (old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	01 Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	1 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	16	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	Required 02	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	02	Provided	MR
	• Hose Box	02	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	Provided	NA
	• Hose Box	NA	Provided	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 & 180 lpm	Provided	MR
	➤ Head of the pump	40 mtr	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	Required	NA	MR
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	5,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

N/25'

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2020/WZ/442 dated 22/10/2020 renewal under Rule 35 of the Delhi Fire Service Rules 2010 is recommended.

24/ADO/MN
24/8/23

(Signature)
Ayc120/W/D

(Signature)
24/8/2023

Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)

DCFOI... I.O. ST...
Dated: 24/8/2023

(Signature)
24/8
25/8/2023
(Signature)
20/8/23

Aoy MN

Sir, F.T is put up for your kind perusal & please
(Signature)