



C101

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/EH/SZ/2023/ 282

Dated: 05/09/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s K LAP (A Unit of Smangs Hospitality LLP), Flat no. 2 & 3, First & Second floor, Khan Market, New Delhi-110003, comprised of Ground plus two Upper Floors was issued Fire Safety Certificate by this department vide letter No. No. F6/DFS/MS/EH/2020/SZ/166 dated 27/11/2020. The premises was re-inspected by the officer concerned of this department on 31/08/2023 in the presence of Mr. Mahesh (Manager) and found that the said eating house building have deemed complied with the fire prevention and Fire Safety arrangement in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy Class-D "Assembly building" (Restaurant) as above with effect from 05/09/2023 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 05/09/2023 at New Delhi by.


(ATUL GARG)
DIRECTOR
Delhi Fire Service

Copy to :-

1. M/s K LAP (A Unit of Smangs Hospitality LLP), Flat no. 2 & 3, First & Second floor, Khan Market, New Delhi-110003. MHA Portal ID-2023082515222 & 2021040612265(Old App.) dated 26/08/2023.
2. The Joint Commissioner of Police (Lic.)Licensing Unit, 1st Floor, Police Station Defence Colony, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The Basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: **M/s KLAP (A Unit of Smangs Hospitality LLP),**
: Flat no. 2& 3, First & Second floor, Khan
: Market, New Delhi-110003.
2. Type of Occupancy : **Assembly "Group-D"(Restaurant)**
3. Building Comprised of : **Ground plus two upper floors.**
4. Type of Case : **Renewal**
5. Details of previous NOC : Nil : **F6/DFS/MS/EH/2020/SZ/166 dated 27/11/2020**
6. Fire Safety directives Letter No. : Nil
7. Date of inspection : **31/08/2023**
8. Name of the Inspecting Officer : **A.D.O. (S.J.) Santosh Kumar**
9. Name and designation of Officer
from the building side : **Mr. Mahesh (Manager)**
10. Year of Construction : **2008 & 2009**
11. Applicant's No. : **MHA ID. 2023082515222 & 2021040612265**
: **(Old App.) dated 26/08/2023**

S No	Minimum standards on fire prevention and fire safety U/R 33	Old FSC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	6m	MR
	• Gate width	NA	Directly accessible from main road	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos	2 Nos	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.0 m each	1.0 m each	MR(old case)
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	01 No	01 No	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1m	1m (Final Exit)	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 ACPH	NA	N/A
	• Upper floors	12 ACPH	Exhaust Fans Provided	MR
5.	Fire Extinguishers			
	• Total numbers	Required	6 Nos	M/R
	• Types	ABC/CO ₂	Provided	M/R
	• ISI marking	Required	Provided	M/R

6.	First – Aid Hose Reels			
	• Total numbers on each floor	01 No.	Provided	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	Smoke & Heat	N/A
	• Location of Main Panel	N/A	Provided	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	Provided	N/A
	• Hooters' Location	N/A	Provided	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Ground Floor	N/A	N/A	N/A
	• Upper Floor	N/A	Provided	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 no.	Provided	MR
	• Hose Box	01 no.	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 & 180 LPM	Provided	MR
	➤ Head of the pump	Required	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltr.	10,000 Ltr.	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	One Co2 type extinguisher provided near electrical panel	N/A

Note- Shortcomings issued by this department vide letter no F6/MS/DFS/MS/EH/2023/SZ/461 dated 24/08/2023 have been complied.

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/EH/2020/SZ/166 dated 27/11/2020 renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Santosh Kumar
 23/08/23
 Signature of the Inspecting Officer
 Name : Santosh Kumar
 Designation : A.D.O. (S.J.)

D.O. (Santosh)
msb
24/09/23
CFO
4/9/2023
Director
5/9/23

FT PS
And/Dr. San
25/09/23
P.F.D