



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/FW/NDZ/2023/433

Dated :- 12 .09.2023

FIRE SAFETY CERTIFICATE

Certified that the M/S GSP Fireworks located at shop no. 43, Ram Nagar Market, Main Qutab Road, New Delhi, running the trade of sale and possession of 300 Kg. fireworks and 1200 Kg. Chinese sparkles at the ground floor shops owned/occupied by Vishal Sehgal, was earlier granted FSC by this department vide letter No.F6/DFS/MS/FW/NDZ/2020/340 dated 28/08/20. Now, the premises was re-inspected by the officers concerned of this department on 31/08/2023 in the presence of Mr. Mukesh Yadav and found that the said building has deemed complied with guidelines issued by Addl. Commissioner of Police (Lic.) and that the premises is fit for occupancy class Fire Works with effect from ..12.09.2023. for period of three years. Subject to conditions mentioned below.

Issued on12.09.2023.....at New Delhi by.

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), 1st floor, P.S. Defence Colony, New Delhi.
2. Mr. Vishal Sehgal, M/S GSP Fireworks, Shop no. 43, Ram Nagar Market, Main Qutab Road, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction and storage of fire crackers as per authorization shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is strictly prohibited.

18
INSPECTION REPORT

1. Name & address of the building M/S GSP Fireworks located at shop no. 43, Ram Nagar Market, Main Qutab Road, New Delhi
2. Type of occupancy:- Fire Works Shop (Building comprises Ground floor only)
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/FW/NDZ/2020/340 dated 28/08/20.
5. Fire safety directives No.- N/A
6. Date of inspection:- 31/08/23
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CD)
Sh. Rajinder Atwal (DO/CD)
8. Name & designation of officer
From the building side:- Mr. Mukesh Yadav
9. Year of construction:- 2013
10. Applicant's letter No:- email <centralartservices@gmail.com> dated 08/08/23.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Required	09 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	03 Nos.	03 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR

~ 6

N/A

	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A

✓

10/


2/10

	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: No smoking sign board. Sand buckets & water buckets provided.			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no.F6/DFS/MS/FW/NDZ/2020/340 dated 28/08/20 under rule 35 (6) of DFS Act 2007 & Rules 2010 .Accordingly DFA is put up for kind perusal and approval / signature please , is recommended.

Signature of the Inspecting Officer


4/9/23

Name :- Rajinder Atwal
Designation :- DO (CD)

Signature of the Inspecting Officer


4/9/23

Name :- Ravinder Singh
Designation :- ADO (CC)

~~Dy. CEO (N02)~~

~~King~~
8/9/23

~~C.F.O.~~

~~6/9/2023~~

~~Director~~

~~11/9/23~~

~~11/9~~

~~DO CD~~

~~ADO/CC~~