

C 64

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F6/DFS/MS/School/WZ/2023/628

Dated: 12/09/2023

FIRE SAFETY CERTIFICATE

Certified that the Little Fairy Public School located at Ashok Vihar, Phase- IV, New Delhi - 110052, is running at Ground + 02 upper floors in a building comprised of Ground + 03 upper floors, was issued FSC vide letter No. F6/DFS/MS/WZ/2019/2075 dated 29/10/2019 (for ground + 02 upper floors). The premises was re-inspected by the officer concerned by this department on 25/08/2023 in the presence of Ms. Bimla Khurana (Vice Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have deemed complied with fire prevention & fire safety requirements in accordance with DOE Circular 3298-3398 dated 17/01/2011/NBC Part IV and that the premises is fit for occupancy class "Educational" (Group B) with effect from 12/09/2023 for a period of three years in accordance with effect from Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010. Conditions mentioned below.

Issued on ..12/09/2023.. at New Delhi.

(Atul Garg)
Director

Copy to: -

1. The Principal, Little Fairy Public School located at Ashok Vihar, Phase- IV New Delhi - 110052.
2. Director of Education, Old Sectt. Delhi-110054.

Following fire safety directives must be adhered to:-

1. The 3rd floor shall not be used for school activity, if it is use for school activity the FSC shall be null and void.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

11/9/2023

INSPECTION REPORT

1. Name & address of the building	Little Fairy Public School, Ashok Vihar Ph- IV, New Delhi – 110052.
2. Type of Occupancy	Educational
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/WZ/School/2019/2075 dated 29/10/2010- for ground plus two upper floors only
5. Fire Safety directives letter No	DOE Circular No. 3298-3398 dated 17/01/2011
6. Date of inspection	25/08/2023
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Ms. Bimlesh Vice Principal
9. Year of Construction	Before 2011 (As per prev. insp. report dated 29/11/2022)
10. Applicant's letter No.	Letter No. LFPS/AV/08/23/1341 dated 18/08/2023

* The School is running at ground plus two upper floors in a building comprised of ground Plus three upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35 (6)/DOE 3298-3398 dt. 01/03/2011	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided (05 mts)	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	Old Case	1.23, 1.21mtr	MR being old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	NA	NA
	f. Width of Corridor	NR	NR	NR
	g. Door Size	1.0 mt.	0.98 mt	MR being old case
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5	Fire Extinguishers			
	• Total numbers	15 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

[Handwritten signatures]

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA		Provided	MR
9	Public Address System.	Required		
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	Provided	---
	• Number of hydrants per floor	NA	Provided	---
	• Hose Box	NA	Provided	---
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	---
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

Handwritten marks and signatures at the bottom of the page.

16 Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA
	• Pressurization of Lift lobby	NA	NA
	• Communication In lift Car	NA	NA
	• Fireman's Grounding Switch	NA	NA
	• Lift Signage	NA	NA
17	Standby power supply	NA	NA
18 Refuge Area.			
	➤ Total Area	NA	NA
	➤ Location	NA	NA
19 Fire Control Room			
	• Detector System Panel	NA	NA
	• Flow Switch Panel	NA	NA
	• PA System Panel	NA	NA
	• Batter backup	NA	NA
	• Building Floor Plans	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided MR

Note: - The 3rd floor shall not be used for school activity, if it is use for school activity the FSC shall be null and void.

The fire protection systems provided in the building were checked and found functional at the time of inspection. The shortcoming issued by this department vide letter no. F6/DFS/MS/School/WZ/2022/734 dated 06/12/2022 has been complied.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F6/DFS/MS/WZ/2019/2075 dated 29/10/2019 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

3/ADO/MN
29/8/23

~~Dy CRO/W12~~

~~Signature
31/8/2023~~

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

FO/1058
04/09/23

~~Signature
4/9~~

~~Signature
5/9/2023~~

~~Director~~

~~Signature
5/9/23~~

~~Signature
04/9/23~~

~~Signature
5/9~~

~~ADO (MN)~~