



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/School/2023/NDZ/ 634

Dated: 14/09/2023

FIRE SAFETY CERTIFICATE

Certified that New Modern Public School running on ground and first floor of the building comprised of ground plus two upper floors located at 1/7279, East Gorakh Park, Shahdara Delhi-110032, owned/occupied by New Modern Public School was issued FSC vide letter No. F.6/DFS/MS/School/2016/NDZ/1508 dated 14/10/2016. The premises was re-inspected by the officer concerned of this department on dated 25/08/2023 in the presence of Mrs. Suman Ahuja (HM) and found that all the fire prevent in and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by the Director of Education and that the building/premises is fit for occupancy class 'Educational Building (Group-B)' with effect from 14/09/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 14/09/2023..... at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
o/c

To:-

The Principal
New Modern Public School located at 1/7279,
East Gorakh Park, Shahdara Delhi-110032

Copy to:-

The Dy. Director of Education
B-Block, Yamuna Vihar Vihar, New Delhi-110092

Conditions for the validity of Fire Safety Certificate

1. Fire Safety Certificate is valid for ground and first floor only. Applicant has submitted an undertaking dated 25/08/2023 that he will not use second floor for school purpose failing which this FSC should be treated null & void.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

- N/A.
1. Name & address of the building : New Modern Public School at 177279,
East Gorakh Park, Shahdara, Delhi-110032.
 2. Building is comprised of : G+2 (School running at G+1 floor only)
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC letter : F6/DFS/MS/School/2016/NDZ/1508 dt 14/10/2016
 6. Fire Safety directive letter No. : F16/Estate/CC/FireSafety/2011/3298to3398 dt-01/03/11
 7. Date of Inspection : 25/08/2023
 8. Name of the Inspecting officers : ADO(Shah), Deepak Kumar
 9. Name and designation of Officer
from the building side : Mrs. Suman Ahuja (HM)
 10. Year of Construction : 1997
 11. Applicant's letter No : Nil Dated- 07/08/2023

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	DoE Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtrs.	06 mtrs.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 nos.	02 nos.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper floor	1.50 mtrs.	1.10 mtr & 0.85 mtr	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	01 no.	N/A
	e. Width of Corridor	1.50 mtrs	1.50 mtrs	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	04 nos.	04 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

2.

06	First-aid-Hose Reels.			
	Total numbers on each floor	N/A	01 no. provided each floor	MR
	• Length of hose reel hose	N/A	01 no. provided each floor	MR
	• Nozzle diameter	N/A	01 no. provided each floor	MR
07	Automatic fire detection and alarming system..			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump house access	N/A	N/A	N/A
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	450 Lpm	N/A
	➤ Head of the pump	N/A	40 mtr	N/A
	➤ Power supply	N/A	Provided	N/A
	➤ Auto Starting of pump	N/A	Provided	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	Provided	MR
	• Overhead Tank capacity	N/A	10,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR

✓

50/

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Note:- Building comprised of ground plus two upper floor but management has given undertaking dated 25/08/2023 at C-22 that they will not use second floor for school purpose and any purpose in any case. FSC is recommended for ground and first floor only.

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule the FSC issued vide letter No. F.6/DFS/MS/School/2016/NDZ/1508 dt 14/10/2016 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Deepak Kumar
28/08/2023
Signature of the Inspecting Officer
Name :- Deepak Kumar
Designation :- A.D.O (Shd)

SFA Ad.
DO/ED *Deepak Kumar*
29/08/2023

Dy. CFO (NDZ)

Deepak Kumar
31/08/23

CFO.
Deepak Kumar
9/9/2023
Director
11/9/23

Deepak Kumar
11/9/23