

C 17

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6/DFS/MS/2023/School/WZ/631

Dated: 13/09/2023

FIRE SAFETY CERTIFICATE

Certified that the Rohini Public School, Plot No.50/4, Naharpur, Sector-7, Rohini, Delhi-85, comprised of building Ground + 02 upper floors (School is running at Ground + 01 upper floor only) owned/occupied by Rohini Public School was granted FSC by this department vide letter No. F.6/DFS/MS/2019/WZ/245 dated 31.01.2019. The premises was re-inspected by the officer concerned of this department on 01.09.2023 in the presence of Mr. M. S. Saini (Manager) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from13/09/2023 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ...13/09/2023... at New Delhi


(Atul Garg)
DIRECTOR
Ph; 011-23414000
eu
Sgt

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Rohini Public School, Plot No.50/4, Naharpur, Sector-7, Rohini, Delhi-85.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Fire+Safety+Acts+and+Rules/>
<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Forms>

N/A

INSPECTION REPORT

1. Name & address of the building : Rohini Public School, Plot No.50/4, Naharpur, Sector-7, Rohini, Delhi-110085.
2. Type of Occupancy : Educational
3. Type of Case : Renewal Gr. + 02 floor (School is running Gr.+ 01 upper floor)
4. Details of Previous NOC : F.6/DFS/MS/2019/WZ/245 dated 31.01.2019.
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2005.
6. Date of inspection : 01.09.2023
7. Name of Inspecting Officer : Sh. Ajay Kumar Sharma (ADO Rohini)
8. Name and designation of officers
From the building side : Mr. M. S. Saini (Manager)
9. Year of Construction : 1994
10. Applicant's letter No. : OD No. 5236 dated 21.08.2023.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Circular	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5m	1.25m & 1.20m	MR since 1994
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	06nos.	08nos.	MR
	• Types	ABC/CO2	ABC-08nos.	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA

(Signature)

(Signature)

2/6

Spec
Pro
The fir

8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System	NA	NA	NA
	• Basement	NA	NA	NA
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants	NA	NA	NA
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants	NA	NA	NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements	NA	NA	NA
	• Ground Level	NA	NA	NA
	➢ Discharge of main Pump	NA	NA	NA
	➢ Head of Main pump	NA	NA	NA
	➢ Number of main pumps	NA	NA	NA
	➢ Jockey Pump out put	NA	NA	NA
	➢ Jockey pump head	NA	NA	NA
	➢ Standby Pump out put	NA	NA	NA
	➢ Standby Pump Head	NA	NA	NA
	➢ Auto Starting/Manual Stopping	NA	NA	NA
	➢ Pump House Access	NA	NA	NA
	• Terrace level	NA	NA	NA
	➢ Discharge of pump	NA	NA	NA
	➢ Head of the pump	NA	NA	NA
	➢ Power Supply	NA	NA	NA
	➢ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting	NA	NA	NA
	• Underground tank capacity	NA	NA	NA
	➢ Draw-off connection	NA	NA	NA
	➢ Fire service inlet	NA	NA	NA
	➢ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage.			
16.	Provision of Lifts.	NA	NA	NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply			
18.	Refuge Area.	NA	NA	NA
	➢ Total Area	NA	NA	NA
	➢ Location	NA	NA	NA
19.	Fire Control Room	NA	NA	NA
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA

Any

29

Special Fire Protection System for Protection of special Risks, if any:

NA

NA

NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in Director of Education Circular, the FSC issued vide letter no. F.6/DFS/MS/2019/WZ/245 dated 31.01.2019 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

[Handwritten Signature]
4/9/23

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

Dy. CFO (WZ)

[Handwritten Signature]
8/9

CFO

[Handwritten Signature]
6/9/2023

Director

[Handwritten Signature]
11/9/23

8/9
5/9/2023

FT letter is put up for kind
perusal and signature please.

Director

[Handwritten Signature]
11/9/23

[Handwritten Initials]