

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2023/SZ/ 638

Dated: 14/09/2023

FIRE SAFETY CERTIFICATE

Certified that the Tagore School, 18, Mayapuri Marg, Mayapuri, New Delhi-110064, comprised of two blocks namely A-Block & B-Block. A-Block is having ground floor plus three upper floors and B-Block having basement, ground floor plus three upper floor was issued FSC by this department vide letter No. F.6/DFS/MS/School/2020/SZ/86 dated 02/03/2020, owned/occupied by the Tagore School. The school was re-inspected by the officer concerned of this department on 28/08/2023 in the presence of Sh. Mohit Kumar Ahuja (Principal) and found that the School have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (Except Bank on ground floor in Block-B) is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....14/09/2023..... at New Delhi.

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Manager,  
Tagore School Block-B, 18, Mayapuri Marg,  
Mayapuri, New Delhi-110064.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. Basement shall be used as per the building bye laws.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.



N/17

Comprised of two blocks namely Block-A & Block-B. Block-A having ground plus three upper floors & Block-B is having basement, ground plus three upper floors and both blocks are interconnected at each floor level.

### INSPECTION REPORT

1. Name & address of the building : Tagore School (Sr. Sec.) 18, Mayapuri Marg, Mayapuri, New Delhi-64
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/School/2020/SZ/86 dated 02/03/2020
5. Fire Safety directives letter No : N/A
6. Date of inspection : 28/08/2020
7. Name of Inspecting Officer : A.D.O. R.K.Yadav
8. Name and designation of officers  
From the building side : Sh. Mohit Kumar Ahuja (Principal)
9. Year of Construction : Before 2010
10. Applicant's letter No. : Form 'J' & Form "K" & TGRS/2023-24/135 dated 16/08/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible (06 mtrs.) 4.5 mtrs N/A	12 mtrs 06, 4.5 & 5.8 mtrs N/A	MR MR N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits (Both blocks are interconnected at each floor level)</b>			
	a. Number of staircases			
	• Upper Floors	02 no.'s	03 no.'s	MR
	• Basements	02 no.'s	02 no.'s	MR
	b. Width of staircases			
	• Upper Floor	1.50 & .75 m	1.67 m, 1.68 m & 1.0 m	MR
	• Basements	1.50 & .75 m	1.67 & 1.24 m	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	Required	One in each block	MR
		1.50 m	1.75m	MR
	f. Door Size	1.0 m	1.0 m (double door)	MR
3.	<b>Compartmentation</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	<b>Smoke Management System</b>			
	• Basements	Required	Exhaust fans are provided	MR
	• Upper floors	Required	Natural ventilation	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	20 no.'s	Provided	MR
	• Types	ABC/CO <sub>2</sub> type	Provided	MR
	• IS marking	ISI marked	ISI marked	MR
6.	<b>First-Aid Hose Reels (Both blocks are interconnected at each floor level)</b>			
	• Total numbers on each floor	02 no.'s/floor	Provided	MR
	• Length of hose reel hose	30 mtrs	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR



7.	<b>Automatic fire detection and alarming system</b>			N/A
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	<b>MOEFA</b>	N/A	N/A	N/A
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			MR
	• Basement	Required	Provided	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			N/A
	• Size of riser/down-comer	N/A	100 mm	N/A
	• Number of hydrants per floor	N/A	One	N/A
	• Hose Box	N/A	One	N/A
12.	<b>Yard Hydrants</b>			N/A
	• Total number of hydrants	N/A	One	N/A
	• Hose Box	N/A	One	N/A
<b>(Common with Block-A)</b>				
13.	<b>Pumping Arrangements</b>			
	• Ground Level			N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	• Terrace level			MR
	➤ Pump House Access	450 LPM (02 no.'s)	450 LPM (02 no.'s) provided	MR
	➤ Discharge of pump	40 mtrs	Provided	MR
	➤ Head of the pump	Required	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
<b>(Common with Block-A)</b>				
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	50,000 ltrs	Provided	MR
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	Provided	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15,000 ltrs	15,000 ltrs Provided	MR
		Required	Provided	MR
15.	<b>Exit Signage.</b>			
16.	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	<b>Standby power supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

N/S

/A  
/A  
/A

19.	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificates issued vide letter number F.6/DFS/MS/School/2020/SZ/86 dated 02/03/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:- There is Bank on Ground floor in Block-B, having no connection from school portion and there is separate entry/exit for bank.  
The undertaking submitted by the Principal states that the basement is constructed as per the approved sanctioned plans and is being used for storage.

*R.K. Yadav*  
04/9/2023

Signature of Inspecting Officer  
Name:- R.K. Yadav  
Designation:- Asstt. Divisional Officer

D.O. (South West)  
*[Signature]*  
5/9/23

CFO (S2)  
*[Signature]*  
6/9/2023

Director  
*[Signature]*  
11/9/23

*Asstt. R.K. Yadav*

PTO