

C 80

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2023/ 637

Dated: 14/09/2023

FIRE SAFETY CERTIFICATE

Certified that Vidya Bharati School, Sector-15, Rohini, Delhi-110085, comprised of Ground + Three Upper floors owned/occupied by Vidya Bharti School was issued fire safety certificate by this department vide letter no F-6/DFS/MS/School/WZ/2021/04 dated 05.01.2021. The premises was re-inspected by the officer concerned of this department on 29.08.2023 in the presence of Smt. Sovanika Pal (Principal) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules 2010, and the building/ premise is fit for occupancy under Educational Class with effect from14/09/2023... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010.

Issued on 14/09/2023 at New Delhi by


(Atul Garg)
DIRECTOR
Ph: 011-23414000


Copy to:

1. The Principal, Vidya Bharati School, Sector-15, Rohini, Delhi-110085.
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form''j' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rul es/ http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : Vidya Bharati School, Sector-15, Rohini, Delhi-110089.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Ground + 3 upper floors)
4. Details of Previous NOC : F-6/DFS/MS/School/WZ/2021/04 dated 05.01.2021
5. Fire Safety directives letter No : Director of Education 17.01.2005
6. Date of inspection : 29.08.2023
7. Name of Inspecting Officer : A.K.Sharma ADO (Rohini)
8. Name and designation of officers
From the building side : Smt. Sovanika Pal (Principal)
9. Year of Construction : 1992-93
10. Applicant's letter No. : OD No.4955 dated 08.08.2023,

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	5m	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	• Upper Floors	04	04	MR
	• Basements	N/A	N/A	N/A
	e. Width of staircases			
	• Upper Floor	1.5m	1.5m each	MR
	• Basements	N/A	N/A	N/A
	f. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	04	04	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1m	1m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	18	18	MR
	• Types	ABC/Co2/Wco2	8ABC, 7Wco2 & 3Co2	MR
	• IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	03	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel		N/A	N/A
	• Location of Repeater Panel		N/A	N/A
	• Alternate source of power		N/A	N/A
	• Hooters' Location		N/A	N/A
8.	MOEFA	Required	Provided	MR

✓

✓

9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground & Upper Floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	4"	Provided	MR
	• Number of hydrants per floor	03	Provided	MR
	• Hose Box	03	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	450lpm	Provided	MR
	➤ Head of Main pump	40m	Provided	MR
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	180lpm	Provided	MR
	➤ Jockey pump head	40m	Provided	MR
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	25000ltr	Provided	MR
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

M

28

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DFS/MS/School/WZ/2021/04 dated 05.01.2021. Renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

[Handwritten Signature]
31/8/23

Signature of the Inspecting Officer
Name :- A.K.Sharma
Designation:- ADO/Rohini

Dy. CFO (WZ) -

[Handwritten Signature]
4/18

[Handwritten Signature]
6/9/2023

Director

[Large Handwritten Signature]
11/9/23
ADP/WZ

[Handwritten Signature]
12/8

FF letter is put up for kind
perusal and signature please.

[Handwritten Signature]
Director
22/6/23
m

[Handwritten Signature]
12/8/23

[Handwritten Note]
CCFO
Date: 14/9/2023