

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/ 435

Dated: 15/09/2023

FIRE SAFETY CERTIFICATE

Certified that the CNG Station Located at Khasra No. 85/23 and 108/3, Vilage Bijwasan, Main Najafgarh Kapashera Road, New Delhi – 110061 in a building comprised of Ground Floor owned/ occupied by Indraprastha Gas Limited have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 01/09/2023 in the presence of Mr. Akash Malik (Manager) and found that the said building that the premises is fit for occupancy class "Hazardous" with effect from 15/09/2023 for a period of three years in accordance with OISD179/ Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/09/2023 at New Delhi by.


(Atul Garg)
Director,

Delhi Fire Service

Copy to:

1. The Manager, CNG Station, Khasra No. 85/23 and 108/3, Vilage Bijwasan, Main Najafgarh Kapashera Road, New Delhi – 110061.
2. Sh. Pulkit Bhardwaj Chief Manager (CNG Projects) – Indraprastha Gas Limited, IGL Bhawan Plot no-4, Community Centre, Sector – 09, R.K. Puram New Delhi.110022.
3. The Addl. Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used as per building bye laws 1983.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **CNG Station Located at Khasra No. 85/23 and 108/3, Vilage Bijwasan, Main Najafgarh Kapashera Road, New Delhi.**
2. Type of Occupancy : Group J: Hazardous (CNG Dispensing Station)
3. Type of Case : New (Ground Floor)
4. Details of previous NOC: Nil
5. Fire Safety directives L. No. : F6/DFS/MS/BP/CNG/2022/355 Dated-10/08/22
6. Date of inspection :01/09/2023
7. Name of the Inspecting Officer :Sh.Udai vir singh, ADO (DWK)
8. Name and designation of Officer from the building side : Mr Akash Malik (Manager)
9. Year of Construction : 2023
10. Applicant's letter No. : DFS Outdoor diary No. 4738, dated 09/08/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	OISD/179	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	NA	Directly accessible from road	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

(Handwritten signature)

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage	Required no smoking board	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided DG set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO2 Flooding	Provided for compressor	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
 Name Uday Var Singh
 Designation ADD/DWR

D/SO
5/9/23

CFP(S2)
6/9/2023

Director
11/9/23

ADD/DWR